

Reserve Measurement and Eligibility

MIC Special Session
June 10, 2020

IMM



Monitoring Analytics

Compliance Directives

- **Transparency of eligibility (P 272)**
 - **Resource Classes**
 - **Deselections and exemptions**
 - **Communication with Market Seller**
- **Capability and Performance Measurement (P 273)**
 - **Use of spin max**
 - **Following dispatch**
 - **Software limitations**
- **Ramp rates and software limitations (P 274)**
- **Use of DGP (P 275)**
- **Removal of cap on DR providing reserves (P 278)**

Transparency of Eligibility

- **PJM proposes to disallow reserves from nuclear, wind, solar, hydro, and storage resources except by exception.**
 - **Exceptions must follow clear, documented rules**
 - **Reserves must be able to be calculated using submitted energy offers using the same formula as all other resources providing reserves.**
- **No exceptions to calculating eligibility based on submitted offer parameters.**
- **All resource eligibility should follow the same math and the same process.**

Capability Measurement

- **Synchronized Reserve Max (Spin Max)**
 - Lower than economic max output limit
 - Implies that the resource cannot achieve its eco max in ten minutes, which is the RT SCED look ahead time.
 - If a resource needs a spin max, it also needs a derate for energy.
- **Ramp rates**
 - New rules require accurate ramp rates.
 - With accurate ramp rates, spin max should not be needed.
 - Ramp rates need to be updated to include configuration transitions.

Measurement with Misaligned Intervals

- **New rule caps reserve MW + energy MW in settlements at the resource economic max output MW.**
- **The dispatch and settlement intervals are not aligned.**
 - **SCED calculates a 10 minute resource ramp.**
 - **Resource follows dispatch and provides reserves in the minutes following the SCED case approval.**
 - **Under PJM's proposed fix, the settlement interval occurs later, in the last five minutes before the SCED target time.**
 - **The reserve MW provided and the energy MW produced come from different points in time.**
 - **The calculation will cap reserve MW incorrectly.**

Measurement of VACAR Reserves

- **The interaction between VACAR reserves and PJM reserves should be explicitly accounted for within the market construct.**
- **The measurement of PJM reserves must explicitly account for VACAR reserve requirements.**
- **Capacity resources that clear in the PJM capacity market have the obligation to provide reserves and energy to PJM when called on.**

Performance Measurement

- **Synchronized reserve**
 - **Spin events of 10 minute duration are rare.**
 - **The timing of when the event measurement takes place should be revised.**
 - **Dispatch / settlement interval alignment issues need to be addressed for measuring reserve performance.**



Performance Measurement

- **Nonsynchronized reserve**
 - Performance is based on nonsynch events.
 - PJM never declares nonsynch events.
 - Create a process for converting nonsynch to energy during spin events and shortages. Measure performance based on this process.
- **Secondary reserve**
 - Same issues as nonsynchronized reserve.
 - Proposed penalty of buying back energy when not responding to dispatch is not a sufficient penalty.

Ramp Rates and Software Limitations

- **Important to maintain strong must offer requirement for synchronized reserve.**
- **Market Seller responsibility to submit accurate physical parameters.**
- **If synchronized reserves cannot be provided in 10 minutes, energy cannot be provided in 10 minutes.**
 - **Units should be derated if energy cannot be provided to ICAP according to the ramp rate.**

Degree of Generator Performance (DGP)

- **PJM is eliminating tier 1 reserves, for which it uses the DGP score as for measurement.**
- **DGP is also used to measure energy MW available in SCED.**
- **PJM should clarify that DGP will not be used to calculate synchronized reserves.**
- **Energy should be calculated consistently, also not using DGP.**

Demand Response

- **Secondary reserves should include 30 minute demand response.**



Monitoring Analytics, LLC

2621 Van Buren Avenue

Suite 160

Eagleville, PA

19403

(610) 271-8050

MA@monitoringanalytics.com

www.MonitoringAnalytics.com

