



<b>Effective Date</b>	September 1, 2015
<b>Impacted Manual #(s)/Manual Title(s):</b>	
M-14D: Generator Operational Requirements	
<b>Conforming Order(s):</b>	
N/A	
<b>Associated Issue Tracking Title:</b>	N/A
<b>Committee Approval Path - What committee(s) have already seen these changes?</b>	
OC – first read 7/7/15, second read and endorsement 8/11/15 SOS – 7/29/15	
<b>MRC 1<sup>st</sup> read date:</b>	7/23/2015
<b>MRC voting date:</b>	8/27/2015
<b>Impacted Manual sections:</b>	
Section 7.5 – Cold Weather Generation Resource Preparation	
<b>Reason for change:</b>	
OC review of process following Winter 2014/2015	
<b>Summary of the changes:</b>	
Section 7.5 – Cold Weather Generation Resource Preparation	
Minor process and clarifications changes: <ul style="list-style-type: none"> <li>• Provide alternate dates for initial scheduling</li> <li>• Clarity around Combined Cycle offers and compensation</li> <li>• GO to provide summary of testing results and problems encountered</li> <li>• Use of eDART for acknowledging completion of Cold Weather Preparation Checklist.</li> </ul>	

Potential criteria changes to be considered at 7/7/2015 OC meeting:

- Change exercise period to 11/1 – 1/15
- Change temperature cutoff in southern zones to 40 deg F
- Change allowable daily MWs to 1,200MW