



Reliability Analysis Update

Transmission Expansion Advisory Committee
April 30, 2024

Adjustments to Earlier Approved Projects

Baseline Reliability Projects

Scope Update:

NextEra team recommends that -/+500 MVAR STATCOM is more efficient and with no cost impact. No reliability issues are identified due to the change.

| Upgrade Id | Previous Scope | New Scope | Designated Entity |
|------------|---|---|-------------------|
| B3800.106 | Two 150 MVAR Cap banks and one +500/-300 MVAR STATCOM at Woodside 500 kV substation | Two 150 MVAR Cap banks and one +500/-500 MVAR STATCOM at Woodside 500 kV substation | NextEra |

**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



Be alert to
malicious
phishing emails.

Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com

