

PJM Update to ISAC

Mark Sims, Manager Presented to Independent State Agencies Committee (ISAC) May 24, 2021



2020 RTEP Window 4 Presented at May 11, 2021 TEAC



2020 RTEP Proposal Window 4 - Statistics

- Timeline
 - Window 4 Opened: March 1, 2021
 - Window 4 Closed: April 2, 2021
- 13 proposals received from 5 entities
 - 5 proposals include cost containment provisions
 - 13 proposal include greenfield construction



			Total				
Proposal			Constructio				
ID#	Project type	Project Description	n Cost \$M	Zone	kV Level	Analysis	Flowgate
		Provide a secondary feed to Brewster 69 kV by tapping					
		the existing Cloverdale – E. Wooster 138 kV line, and					
		connecting it to Brewster 69 kV station via a greenfield					
		138/69 kV substation (Fine Fork Station) and a new 5-					
		mile 69 kV line between the greenfield tap location				FERC 715 TO	
862	Greenfield	and the Brewster 69 kV station.	\$17.70	ATSI	138/69 kV	Criteria	AMPT-01
		The Brewster - Iron Man 69kV Transmission Project					
		will include a new 3-position substation					
		interconnecting the West Wilmot - Beartown 69kV					
		transmission line. The proposed project will include a					
		new 69kV transmission line to connect the new					
		substation with a new line position at the Brewster				FERC 715 TO	
185	Greenfield	69kV Substation.	\$7.10	ATSI	69 kV	Criteria	AMPT-01
		Build a 6.5 mile greenfield 69 kV line from Brewster					
		station to the future Alpine station. Expand Alpine					
		station to a 5 breaker ring bus to accommodate the					
		new line from Brewster. Perform station work at				FERC 715 TO	
20	Greenfield	Brewster to accommodate the new line.	\$10.10	ATSI, AEP	69 kV	Criteria	AMPT-01



			LATERCE				
Proposal ID#	Project type	Project Description	Total Construction Cost \$M	Zone	kV Level	Analysis	Flowgate
		Build a greenfield 69 kV station "East Wilmot" to tap the					
		line from Beartown station to the future Alpine station.					
		Build East Wilmot station as a 3 breaker ring bus.					
		Build a 5.3 mile greenfield 69 kV line from Brewster					
		station to East Wilmot station. Perform station work at				FERC 715 TO	
991	Greenfield	Brewster to accommodate the new line.	\$11.80	ATSI, AEP	69 kV	Criteria	AMPT-O
		Build a greenfield 138/69 kV station "Pigeon Run" to tap					
		the South Canton – Apple Creek 138 kV line. Build Pigeon					
		Run station as a 4-breaker station with a 90 MVA 138/69					
		kV transformer.					
		Build a 4.2 mile greenfield 69 kV line from Brewster					
		station to Pigeon Run station. Perform station work at				FERC 715 TO	
380	Greenfield	Brewster to accommodate the new line.	\$13.90	ATSI, AEP	138/69 kV	Criteria	AMPT-O
		Build a greenfield 345/69 kV station "Crossroads" to tap					
		the Harmon – Star 345 kV line. Build Crossroads station as					
		a 4-breaker station with a 90 MVA 345/69 kV transformer.					
		<u> </u>					
		Build a 2.8 mile greenfield 69 kV line from Brewster station to Crossroads station. Perform station work at				EEDC 715 TO	
	Cua a mfi a l d		640.00	ATCI	245/60/54	FERC 715 TO	A NADT O
/4	Greenfield	Brewster to accommodate the new line.	\$19.80	A 151	345/69 kV	Criteria	AMPT-O




Proposal			Total Construction				
ID#	Project type	Project Description	Cost \$M	Zone	kV Level	Analysis	Flowgate
		Build a 3.73 mile greenfield 69 kV line from Harmon station to					
		Brewster station in parallel with the existing AMPT line. Install a					
		new 69 kV breaker at Harmon station and perform related station					
		work to accommodate the new line. Modify the 69 kV bus at					
		Harmon station to convert the existing breaker "B26" into a bus-tie					
		breaker. Perform station work at Brewster to accommodate the				FERC 715 TO	
978	Greenfield	new line.	\$9.50	ATSI	69 kV	Criteria	AMPT-01
		Bring the existing Harmon – Yager 138 kV line "in & out" of Brewster					
		station. Build two separate but parallel 3.46 mile greenfield 138 kV					
		lines from Brewster to the existing Harmon – Yager 138 kV line,					
		approximately 3 miles east of Brewster, and 1.8 miles along the					
		Harmon – Yager 138 kV line from Harmon. Retire the existing					
		Harmon – Brewster 69 kV line, 69 kV buswork at Brewster, and					
		existing 69/12 kV transformers. Replace with 138 kV buswork and			138/69	FERC 715 TO	
839	Greenfield	equipment. Install three 138/12 kV transformers.	\$20.70	ATSI	kV	Criteria	AMPT-01
		Convert the 69 kV yard at Harmon into a six (6) breaker 69 kV ring					
		bus. Build a new 69 kV line from Harmon to Brewster (Brewster-					
		Harmon #2 69kV) in a different ROW and on independent structures					
		than the existing Brewster-Harmon 69 kV line with 556 kcmil ACSR					
		conductor, terminate the line just outside of the Brewster Muni				FERC 715 TO	
105	Greenfield	substation at the customer dead end structure.	\$16.50	ATSI	69 kV	Criteria	AMPT-01




			11111111111				
Proposal	Project		Total Construction				
ID#	type	Project Description	Cost \$M	Zone	kV Level	Analysis	Flowgate
		Expand the Harmon 69 kV bus and add one 69 kV circuit breaker to	3/				
		provide a line exit to Brewster for a second 69 kV line. Build a new					
		69 kV line from Harmon to Brewster (Brewster-Harmon #2 69kV)					
		in a different ROW and on independent structures than the					
		existing Brewster-Harmon 69 kV line with 556 kcmil ACSR					
		conductor, terminate the line just outside of the Brewster Muni				FERC 715 TO	
207	Greenfield	substation at the customer dead end structure	\$9.20	ATSI	69 kV	Criteria	AMPT-O
		Build a 5.5 mile-long 69 kV transmission line from the existing					
		Brewster 69 kV substation to a new three breaker ring bus					
		switchyard on the existing West Wilmot to Beartown 69 kV					
		transmission line. The tap point on the West Wilmot to Beartown					
		69 kV transmission line will be approximately 1.3 miles from West				FERC 715 TO	
610	Greenfield	Wilmot 69 kV substation.	\$13	ATSI, AEP	69 kV	Criteria	AMPT-O
		Building a 4.7 mile-long 69 kV transmission line from the existing					
		Brewster 69 kV substation to a new three breaker ring bus					
		switchyard on the existing West Wilmot to Beartown 69 kV					
		transmission line. The tap point on the West Wilmot to Beartown					
		69 kV transmission line will be approximately 3.7 miles from West				FERC 715 TO	
595	Greenfield	Wilmot 69 kV substation.	\$12.10	ATSI, AEP	69 kV	Criteria	AMPT-O
		Build a 4.4 mile-long 69 kV transmission line from the existing					
		Brewster 69 kV substation to a new 138/ 69 kV substation on the					
		existing Cloverdale to Yager 138 kV transmission line. The new					
		138/ 69 kV substation will involve a three breaker ring, a 138-69 kV					
		step-down transformer and a breaker on the LV side of the step-					
		down transformer. The proposed 138/69 kV substation will be				FERC 715 TO	
373	Greenfield	approximately 6.2 miles from Cloverdale 138 kV substation.	\$15.80	ATSI	138/69 kV	Criteria	AMPT-O













PJM evaluating proposals



New Jersey State Agreement Approach Presented at Special TEAC on May 5, 2021




Problem Statements:

- ➤ Option 1a Onshore Upgrades on Existing Facilities
- ➤ Option 1b Onshore New Transmission Connection Facilities
- ➤ Option 2 Offshore New Transmission Connection Facilities
- ➤ Option 3 Offshore Network



Project Overview – Potential Solution Options







- Four separate problem statements for each of the four options
- Proposals will not impact requirements for first two solicitations
- Proposals can address the default or alternative POIs
 - Alternative POIs will only be considered if sufficient proposals are submitted to address all system needs created by alternative POIs
- PJM/NJBPU will combine full or partial proposals to form complete solution packages
- Proposal submissions should include any linkages with other proposals and impacts of selecting partial solutions



Proposal evaluation considerations

 Largest single contingency, reliability, constructability, cost, risk mitigation, environmental, permitting, experience, flexibility, market value, other metrics

Deliverables

 PJM proposal submittal template, BPU proposal supplemental data collection form, technical analysis files, diagrams and schedules, company information





- PJM and NJBPU will evaluate the proposed solutions that address the posted public policy needs.
- Solution packages that will be considered may consist of the following:
 - Combinations of Partial and full proposed solutions
 - Solution packages that achieve less than the full 7500 MWs
 - Solution packages that use alternate POIs



Offshore Transmission Study Group





SME/Presenter:

Mark Sims, Mark.Sims@pjm.com

Independent State Agencies Committee



Member Hotline

(610) 666 - 8980

(866) 400 - 8980

custsvc@pjm.com