

# DER Trip Impact Study: Methods, Results, and Conclusions

June 14, 2019

DER Ride Through Task Force

Rojan Bhattarai, Argonne National Lab

Andrew Levitt, PJM

- Motivation:
  - Multiple system events (California 2016/17/18, South Australia, Europe 2006) have highlighted the risk posed by lack of ride-through. If DER proliferates in PJM, ride-through should be mandatory.
  - Distribution system protection philosophy differs greatly from Transmission. There is a need to harmonize ride-through requirements to maintain reliability at Transmission and Distribution grids.
- Objective:
  - Parametric analysis to understand the impact of different trip settings & ride through modes on voltage recovery under varying DER deployment.
  - Inform selection of ride through modes and trip timing for implementation of IEEE 1547-2018



# Executive Summary: Preliminary Key Findings

Complex load model findings:

1. **DER without ride through causes impact in all scenarios.**
2. **DER with ride through → minimal impact in all cases.**
3. **DER with momentary cessation ride through mode also → minimal impact** when DER follow the recovery requirements of IEEE 1547-2018.
4. **A trip point of >2 seconds at V < 88% and >320 milliseconds at V < 45% may result in minimal impact** by providing low-voltage ride through times longer than voltage recovery times.
  - However, model limitations mean that Fault Induced Delayed Voltage Recovery on distribution may not be captured—voltage recovery may be longer in reality.

*Load model significantly affects voltage recovery*

--ZIP load models show adequate voltage recovery under all scenarios, however, over 4 GW of DER trip in some scenarios causing frequency concerns.

Complex Load Model Results										
	3 GW DER		8 GW DER		13 GW Med Synch Gen		13 GW DER Lo Synch Gen		13 GW DER No Synch Gen	
NJ BES Fault: North/Central	N	C	N	C	N	C	N	C	N	C
Trip	Modest	Modest	Some	Some	More	More	More	More	More	More
RT	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal
MC50	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal
MC30	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal


	<i>Minimal impact</i>		<i>Some impact</i>
	<i>Modest impact</i>		<i>More impact</i>
			<i>Most impact</i>

Study Project Overview

Summary of Method and Assumptions

Results and Conclusions


Appendix: Detailed Methodology, Assumptions, & Results



*In additional to extensive review and discussion with EPRI, these EPRI references provided significant guidance:*

[1] EPRI. *The New Aggregated Distributed Energy Resources (der\_a) Model for Transmission Planning Studies: 2019 Update. White Paper.* Electric Power Research Institute, Palo Alto, CA: March 2019. 3002015320. [Online] <https://www.epri.com/#/pages/product/000000003002015320/>

[2] EPRI. *Case Studies Analyzing the Impact of Aggregated DER Behavior on Bulk System Performance: Supplemental Project Notice.* Electric Power Research Institute, Palo Alto, CA: March 15, 2019. 3002015415. [Online] <https://www.epri.com/#/pages/product/000000003002015415/>



**We are here**


Study Project Overview

**Summary of Method and Assumptions**

Results and Conclusions

Appendix: Detailed Methodology, Assumptions, & Results

**BES Fault**



**TRIP  
or  
other**



BES Fault in 2031

DER Trip or Ride Through

BES Fault Clearing

T+D Response

DER recovery

2031 case based on 2021 light load:

- Light load → less synchronous generation online to support voltage recovery.
- Distribution of load in 2021LL is consistent with today's actual NJ loading in December at noon.
- Solar DER output is modeled consistent with December at noon.
- RTO power balance per case via electrically distant generators.
- Input from PJM Transmission Ops for Synch Gen commit/dispatch.
- Resulting net exchanges NJ<>PJM not unusual today.


	2021 Light Load		3 GW DER	8 GW DER	13 GW DER Med Synch Gen	13 GW DER Lo Synch Gen	13 GW DER No Synch Gen	
<i>DER</i>	2.1 GW		<i>DER</i>	3.0 GW	8.2 GW	12.6 GW	12.6 GW	12.6 GW
<i>Synch Gen</i>	7.0 GW		<i>Synch Gen</i>	6.2 GW	5.0 GW	6.2 GW	3.7 GW	0.0 GW
<i>Load</i>	13.8 GW		<i>Load</i>	13.8 GW				

3 GW DER = PJM solar deployment forecast for NJ in 2031 → under 10% of annual NJ load from solar DER.

8 GW DER → under 20% of annual NJ load from solar DER.


13 GW DER → under 40% of annual NJ load from solar DER

- Added a DER\_A object to all load buses.
- Changed load from simpler “ZIP” to “Complex” type.
- Equivalent feeder impedance is represented in the model—
  - If load transformer exists in model (most buses), equivalent feeder impedance is already represented in existing transformer impedance.
  - If no load transformer in model, added load transformer and equivalent feeder as shown at right. 2 sensitivities cases for this feeder impedance. New feeders are 12.47 kV. EPRI feedback: behavior not expected to vary with feeder voltage.




- 8 DER\_A behavior scenarios:
  - Return to normal operations from Momentary Cessation was subject of careful attention relative to IEEE 1547-2018.
- DER\_A scenarios tested against infinite bus to confirm real and reactive power behavior cycle-by-cycle and correspondence with IEEE 1547-2018 requirements

8 DER_A Dynamics Scenarios	
<i>Voltage regulation OFF and:</i>	<i>Voltage regulation ON and:</i>
Trip	Trip
Ride Thru	Ride Thru
Momentary Cessation for $V < 30\%$	Momentary Cessation for $V < 30\%$
M.C. < 50%	M.C. < 50%



- Used PSS/E to screen all NJ faults for most MW of load with  $V < 55\%$  during fault (e.g., red areas in figure at right for fault at 500 kV bus “S”).
- Chose among the 10 most severe faults that reflect a diversity of NJ network, load, and DER conditions:
  - 230 kV (“North NJ”)
  - 500 kV (“Central NJ”)
  - 500 kV (“South NJ”)
  - Fourth fault case: 500 kV
  - Fifth fault case: 230 kV



Study Project Overview

Summary of Method and Assumptions

**Results and Conclusions**

Appendix: Detailed Methodology, Assumptions, & Results

Complex load model findings:

1. **DER without ride through causes impact in all scenarios.**
2. **DER with ride through → minimal impact in all cases.**
3. **DER with momentary cessation ride through mode also → minimal impact** when DER follow the recovery requirements of IEEE 1547-2018.
4. **A trip point of >2 seconds at V < 88% and >320 milliseconds at V < 45% may result in minimal impact** by providing low-voltage ride through times longer than voltage recovery times.
  - However, model limitations mean that Fault Induced Delayed Voltage Recovery on distribution may not be captured—voltage recovery may be longer in reality.

*Load model significantly affects voltage recovery*

--ZIP load models show adequate voltage recovery under all scenarios, however, over 4 GW of DER trip in some scenarios causing frequency concerns.

Complex Load Model Results										
	3 GW DER		8 GW DER		13 GW Med Synch Gen		13 GW DER Lo Synch Gen		13 GW DER No Synch Gen	
NJ BES Fault: North/Central	N	C	N	C	N	C	N	C	N	C
Trip	Modest	Modest	Some	Some	More	More	More	More	More	More
RT	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal
MC50	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal
MC30	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal	Minimal

	<i>Minimal impact</i>		<i>Some impact</i>
	<i>Modest impact</i>		<i>More impact</i>
			<i>Most impact</i>

# Finding 1. DER without ride through causes impact in all scenarios


		Complex Load Model Results									
		3 GW DER		8 GW DER		13 GW Med Synch Gen		13 GW DER Lo Synch Gen		13 GW DER No Synch Gen	
NJ BES Fault: North/Central		N	C	N	C	N	C	N	C	N	C
MW DER Tripped	<b>Trip</b>	790	823	2,628	2,351	4,385	3,458	5,080	4,281	3,615	3,202

	<i>Minimal impact</i>	PJM plans the system so <u>no</u> generation trips following normally-cleared transmission fault.
	<i>Modest impact</i>	Any loss of generation trip caused by fault is a concern. For reference, loss of < 1,700 MW is within PJM typical operational contingency planning.
	<i>Some impact</i>	PJM's worst recent historical single-event loss of generation is <2,700 MW.
	<i>More impact</i>	Eastern Interconnection's worst recent single-event loss of generation is ~4,500 MW
	<i>Most impact</i>	

# Finding 1. DER Trip Causes Poor Voltage Recovery

13 GW DER-Lo Synch Gen Case (4 GW Synch Gen )


Scenario: complex load, Central NJ fault, voltage Regulation off, high feeder impedance



# Finding 1. DER Trip Causes Poor Frequency

## 13 GW DER-Lo Synch Gen Case (4 GW Synch Gen )

Scenario: complex load, Central NJ fault, voltage Regulation off, high feeder impedance



NERC 2013 “Eastern Frequency Response Study” —

“On August 4, 2007, a major event included the loss of approximately 4,500 MW of generation...The lowest frequency in that event, 59.868 Hz, occurred at about 1 min after the event.

<https://www.nrel.gov/docs/fy13osti/58077.pdf>



# Finding 2 and 3. DER with ride through (including momentary cessation) → minimal impact in all cases

		Complex Load Model Results									
		3 GW DER		8 GW DER		13 GW Med Synch Gen		13 GW DER Lo Synch Gen		13 GW DER No Synch Gen	
NJ BES Fault: North/Central		N	C	N	C	N	C	N	C	N	C
MW DER Tripped	RT	0	0	0	0	0	<100	0	<100	0	<100
	MC50	0	0	<100	0	0	0	0	0	<100	0
	MC30	0	0	0	0	<100	0	0	0	<100	0

 *Minimal impact* PJM plans the system such that no generation trips following a normally-cleared transmission contingency.

13 GW DER-Lo Synch Gen Case (4 GW Synch Gen)


Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance




13 GW DER-Lo Synch Gen Case (4 GW Synch Gen)

Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance, **transmission busses**


**RIDE THROUGH**



**MOMENTARY CESSATION < 30%**



**MOMENTARY CESSATION < 50%**





**13 GW DER-Lo Synch Gen Case (4 GW Synch Gen )**

Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance, **transmission busses**

**RIDE THROUGH**

**MOMENTARY CESSATION < 50%**




# Finding 4. Trip >2 seconds at $V < 88\%$ & >320 milliseconds at $V < 45\%$ may be adequate

For each ride through and momentary cessation case, voltage at each DER bus (except 1 or 2 buses in worst case scenarios) recovered faster than:

- Voltage recovery to > 88% in < 1.84 seconds (UV1)
- Voltage recovery to > 45% in < 160 milliseconds (UV2)

- IEEE 1547-2018 allows a 160 millisecond “grace period” exemption from ride through requirement prior to trip time.
- Therefore, a 2-second trip time implies a **1.84 ride through requirement** (assuming the ride through requirement is otherwise > 1.84 seconds).
- Likewise, a 320 millisecond trip time implies a **160 ride through requirement**.




# Finding 4. Trip >2 seconds at $V < 88\%$ & >320 milliseconds at $V < 45\%$ is minimal impact

For each ride through and momentary cessation case, voltage at each DER bus (except 1 or 2 buses in worst case scenarios) recovered faster than:

- Voltage recovery to  $> 88\%$  in  $< 1.84$  seconds (UV1)
- Voltage recovery to  $> 45\%$  in  $< 160$  milliseconds (UV2)

Caveat: the Complex Load Model used in this study is known to have limited ability to simulate “Fault Induced Delayed Voltage Recovery” caused by loads on distribution.

- PJM is not aware of any detailed studies of distribution-level FIDVR in the Mid-Atlantic or Midwest.
- Actual recovery to  $V > 88\%$  may be slower than simulated.
- Therefore, UV1 trip times longer than 2 seconds and UV1 voltage thresholds below 88% (where practicable) are generally preferred.
- In areas where distribution-level FIDVR is known, UV1 trip times should be longer than 2 seconds.




Study Project Overview

Summary of Method and Assumptions


Results and Conclusions

Appendix: Detailed Methodology, Assumptions, & Results



- Two feeder equivalent impedance sensitivities for those buses that did not already have a substation load step down transformer:
  - Input from NJ utilities, existing PJM complex load model for NJ, IEEE standard models, EPRI

<i>(X and R in per unit vs. model load base)</i>	R	X	X/R
Low impedance case	3%	15%	5
High impedance case	9%	18%	2



- PSS/E 33.12 required for DER\_A model. Recompiled existing custom gen models from PJM's model in PSS/E 33.10 using Intel Visual Fortran.
- Script builds static cases by starting with 2021LL case, adding some DER, re-solving, and iterating until final scenario is reached.
- Likewise, script dials down or up Synch Gens incrementally, solves, and iterates.
- Total of 10 static cases. All found stable initial load flow solutions.
- All PJM transmission lines at boundary of NJ utilities, and 500 kV lines in vicinity, maintained within thermal, reactive, and N-1 limits
- Most remaining transmission lines in the vicinity within thermal and reactive limits as well.
  - Any violations examined and deemed inconsequential using engineering judgement.


	3 GW DER	8 GW DER	13 GW DER Med Synch Gen	13 GW DER Lo Synch Gen	13 GW DER No Synch Gen
Lo Feeder Z	<i>Load Flow</i>	<i>Load Flow</i>	<i>Load Flow</i>	<i>Load Flow</i>	<i>Load Flow</i>
Hi Feeder Z	<i>Load Flow</i>	<i>Load Flow</i>	<i>Load Flow</i>	<i>Load Flow</i>	<i>Load Flow</i>

Results were minimally sensitive to feeder impedance assumptions—results are generally shown from high impedance case (R = 9%, X = 18%).


- ZIP model scenarios used default from the 2021LL model.
- Complex load model scenarios:
  - Parameters originally from existing complex load parameterization on file at PJM, validated using load type share ratios from peak load forecast.
  - For some areas, PJM reduced small motor component vs. value on file at PJM.
  - Per internal PJM guidance, loads  $< 5$  MVA were left as ZIP, as well as loads with poor power factor.
  - In certain cases, several complex load objects were manually switched to ZIP.

Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance, **transmission bus voltages**

### TRIP




### RIDE THROUGH




Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance, **transmission bus voltages**

## TRIP



## RIDE THROUGH





13 GW DER-Med Synch Gen Case (6 GW Synch Gen )

13 GW DER-Lo Synch Gen Case (4 GW Synch Gen )

Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance, **transmission bus voltages**

**TRIP MED SYNCH GEN**



**TRIP LO SYNCH GEN**



Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance


### TRIP LO SYNCH GEN: DISTRIBUTION

### TRIP LO SYNCH GEN: TRANSMISSION




Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance

### ***TRIP: DISTRIBUTION***



### ***RIDE THROUGH MC50: DISTRIBUTION***




# Results: Ride Through vs. Momentary Cessation


13 GW DER-Lo Synch Gen Case (4 GW Synch Gen)

Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance, **transmission busses**


**RIDE THROUGH**



**MOMENTARY CESSATION < 30%**




**MOMENTARY CESSATION < 50%**




Complex Load, Central NJ fault, Voltage Regulation off, high feeder impedance, **transmission busses**


**RIDE THROUGH**



**MOMENTARY CESSATION < 30%**



**MOMENTARY CESSATION < 50%**




3 GW DER (6 GW Synch Gen )

8 GW DER (5 GW Synch Gen )


13 GW DER (6 GW Synch Gen )

Complex Load, Trip, Central NJ fault, Voltage Regulation off, high feeder impedance, **transmission and distribution bus voltages**

**3 GW DER**



**8 GW DER**



**13 GW DER**

