



Performance Assessment Interval Trigger Over ICCP Project



Operating Committee Meeting
November 7, 2017
Alpa Jani

Performance Assessment Interval Trigger Over ICCP Project

WHAT is a Performance Assessment Interval?

The Real-time Settlement Interval for which an Emergency Action has been declared by PJM. Performance Assessment Intervals are delineated by PJM's declaration of Emergency Actions.
Manual 18 Section 8 *(Updates in progress at stakeholder meetings)

WHERE are Performance Assessment Interval Triggers communicated?

The Emergency Procedures tool informs PJM members, PJM personnel and other interested parties about emergency events (including the Performance Assessment Interval Triggers)

In addition to viewing the emergency event information in the Emergency Procedures tool, users may request email and text notification of the events from the Emergency Procedures Tool
<http://www.pjm.com/-/media/etools/emerg-procedures/emergency-procedures-email-notification-setup.ashx?la=en>

WHY was the Performance Assessment Interval Trigger Over ICCP project started?

Members requested an additional method of communication of the Performance Assessment Interval Triggers over ICCP
*Emergency Procedures tool will continue to be tool of record for Performance Assessment Interval Triggers

(Steps 1-10 in Sections 2 and 5 of Emergency Procedures Manual 13)

Pre-Emergency Load Management Reduction Action (30, 60 or 120 minute)

Emergency Load Management Reduction Action (30, 60 or 120 minute)

Primary Reserve Warning

Maximum Generation Emergency

Emergency Voluntary Energy Only Demand Response Reductions

Voltage Reduction Warning

Curtailment of Non-Essential Building Load

Deploy All Resources Action

Manual Load Dump Warning

Voltage Reduction Action

Manual Load Dump Action

Warnings

Actions

(Section 5.7 of Emergency Procedures Manual 13)

Load Shed Directive

EXAMPLE


Emergency Procedure Message: Maximum Generation Emergency Action

Date and Time: 4/21/15 18:45

Region: FE-PN (Transmission Zone PA- Former GPU: Penelec (FirstEnergy; FE-East) [MIDATL]

TOOLS for COMMUNICATION

- All Call Issued (**Record of Data**)
- Emergency Procedure (**Record of Data**)
 - Maximum Generation Emergency Action Issued in Emergency Procedures Tool
 - Email and text notifications may be set up
- PAI over ICCP Communication
 - Indicator sent via ICCP to units in the FE-PN zone
 - Members to update PI displays for operators to view impacted units
- PJM Now App
 - Alerts may be set up for Emergency Procedure Messages



- Updates to ICCP/DNP PI Displays may be made by the members to indicate units impacted by the Performance Assessment Interval Triggers for station operators
- Members will be required to provide confirmation to Opt Into receiving PAI messages over ICCP or DNP (more details on the process to Opt In to be provide at future member meetings)

Additional Project Details will be reviewed at the next OC and Tech Forum Change Meeting:

- Project Status
- Project Milestones
- “Opt In” Process to receive PAI messages over ICCP or DNP