



Public Service Commission of Maryland

PJM Status Reports

- (1) 2011/2012 Base Residual Auction Results Summary**
- (2) “Gap” Generation Analysis Estimates
w/o 502 Junction – Loudoun 500 kV Line in 2011**
- (3) 2010 Update / Expectations**

Michael J. Kormos
Senior Vice President
Reliability Services
May 21, 2008

| Auction Results | RTO | | | EMAAC | | | SWMAAC | | |
|--|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| | 2009 / 2010 | 2010 / 2011 | 2011 / 2012 | 2009 / 2010 | 2010 / 2011 | 2011 / 2012 | 2009 / 2010 | 2010 / 2011 | 2011 / 2012 |
| NEW Demand Response Offered [MW] | 221.0 | 31.1 | 684.5 | 0.0 | 0.0 | 0.0 | 42.2 | 162.7 | 260.2 |
| NEW Demand Response Cleared [MW] | 356.7 * | 46.1 * | 425.9 | 0.0 | 0.0 | 0.0 | 47.1 * | 162.7 | 221.6 |
| DIFERENCE -- NEW Demand Response that did not clear [MW] | (135.7) * | (15.0) * | 258.6 | 0.0 | 0.0 | 0.0 | (4.9) * | 0.0 | 38.6 |
| TOTAL Demand Response Offered [MW] | 936.8 | 967.9 | 1,652.4 | 376.6 | 318.9 | 306.9 | 356.3 | 519.0 | 779.2 |
| TOTAL Demand Response Cleared [MW] | 892.9 | 939.0 | 1,364.9 | 372.4 | 306.4 | 231.2 | 356.3 | 519.0 | 740.6 |
| DIFFERENCE – all Demand Response that did not clear [MW] | 43.9 | 28.9 | 287.5 | 4.2 | 12.5 | 75.7 | 0.0 | 0.0 | 38.6 |

* NOTE: DR values appear counter-intuitive, but are correct. In previous year, not all “new” DR cleared; current year new cleared thus exceeds new offered



May 2008 PJM RPM Base Residual Auction: Results and Comparison


| | RTO | | | EMAAC | | | SWMAAC | | |
|--|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| Auction Results | 2009 / 2010 | 2010 / 2011 | 2011 / 2012 | 2009 / 2010 | 2010 / 2011 | 2011 / 2012 | 2009 / 2010 | 2010 / 2011 | 2011 / 2012 |
| Resource Clearing Price [\$/MW-Day] | 102.04 | 174.29 | 110.00 | 191.32 | 174.29 | 110.00 | 237.33 | 174.29 | 110.00 |
| NEW Generation Offered [MW] | 439.2 | 403.6 | 2,203.7 | 92.9 | 124.5 | 693.2 | 0.0 | 0.0 | 220.8 |
| NEW Generation Cleared [MW] | 300.3 | 285.1 | 1,916.1 | 92.9 | 6.0 | 535.2 | 0.0 | 0.0 | 0.0 |
| DIFFERENCE -- NEW Generation that did not clear [MW] | 138.9 | 118.5 | 287.6 | 0.0 | 118.5 | 158.0 | 0.0 | 0.0 | 220.8 |
| UPRATES & REACTIVATED Generation Offered [MW] | 590.1 | 727.3 | 1,243.8 | 128.6 | 178.0 | 205.1 | 32.0 | 0.8 | 186.9 |
| UPRATES & REACTIVATED Generation Cleared [MW] | 590.1 | 727.3 | 1,002.3 | 128.6 | 178.0 | 198.5 | 32.0 | 0.8 | 106.5 |
| DIFFERENCE -- Uprates & Reactivated Generation that did not clear [MW] | 0.0 | 0.0 | 241.5 | 0.0 | 0.0 | 6.6 | 0.0 | 0.0 | 80.4 |
| ALL Generation Offered [MW] | 132,614.2 | 132,124.8 | 136,067.9 | 31,307.6 | 30,926.9 | 31,740.2 | 9,955.4 | 10,409.2 | 10,871.9 |
| ALL Generation Cleared [MW] | 131,338.9 | 131,251.4 | 130,856.6 | 31,278.2 | 30,508.6 | 29,146.4 | 9,558.3 | 10,354.4 | 10,039.3 |
| DIFFERENCE -- All Generation that did not clear [MW] | 1,275.3 | 873.4 | 5,211.3 | 29.4 | 418.3 | 2,953.8 | 397.1 | 54.8 | 832.6 |



May 2008 PJM RPM Base Residual Auction: Incremental Capacity Resource Additions Comparison by Fuel Type



| Generation | Delivery Year | CT/GT | Combined Cycle | Diesel | Hydro | Steam | Nuclear | Solar | Wind | TOTAL |
|---|---------------|---------------|----------------|--------------|--------------|---------------|--------------|------------|--------------|---------------|
| New Capacity Units (ICAP MW) | 2009/2010 | 399.5 | | 23.8 | | 53.0 | | | | 476.3 |
| | 2010/2011 | 283.3 | | 23.0 | | | | | 141.4 | 447.7 |
| | 2011/2012 | 416.4 | 1,135.0 | | | 704.8 | | 1.1 | 75.2 | 2,332.5 |
| Capacity From Reactivated Units (ICAP MW) | 2009/2010 | | | | | | | | | 0.0 |
| | 2010/2011 | 160.0 | | 10.7 | | | | | | 170.7 |
| | 2011/2012 | 80.0 | | | | 101.0 | | | | 181.0 |
| Upgrades to Existing Capacity Resources (ICAP MW) | 2009/2010 | 152.2 | 209.0 | | 162.5 | 61.4 | 194.4 | | 16.5 | 796.0 |
| | 2010/2011 | 117.3 | 743.0 | | 48.0 | 89.2 | 160.3 | | | 1,157.8 |
| | 2011/2012 | 369.2 | 148.6 | 57.4 | | 186.8 | 292.1 | | 8.7 | 1,062.8 |
| TOTAL | | 1977.9 | 2235.6 | 114.9 | 210.5 | 1196.2 | 646.8 | 1.1 | 241.8 | 6624.8 |

2011/2012 Installed Capacity Increase By Fuel Type



| Overloaded Facility | Test Resulting in Highest Overload | Year that Facility Loading Exceeds Conductor Rating |
|------------------------------------|------------------------------------|---|
| Mt. Storm – Doubs 500 kV Line | Load Deliverability | 2011 |
| Pruntytown – Mt. Storm 500 kV Line | Generator Deliverability | 2014 |
| Meadow Brook | 'N – 2' Contingency | 2011 |

- PJM identifies reliability criteria violations, need for additional transmission capability
- PJM Board approves new Loudoun Line



- With Loudoun line in service, PJM system reliability criteria are within limits.
- Presently, PJM has no indication that the Loudoun cannot be completed by 2011 when reliability criteria violations driving the need for the line are first observed.
- PJM's October 2007 initial gap estimate for Mid-Atlantic PJM of 6,500 MW included approximately 1,500 MW for Maryland. PJM's gap estimate represents that amount of area load in excess of area generation that exceeds the transmission capability needed to transfer power into an area to serve that load at risk.
- PJM interprets MD-PSC's request as comprising a set of sensitivity studies to estimate worse case scenarios for gap in light of the October 2007 initial estimate, updated case numbers, and May 2008 PJM RPM Base Residual Auction (BRA) results.

- Mid-Atlantic Load Deliverability...ability of transmission to import power into a specific area when sufficient generation is NOT available in that area to supply load.
- Resource “Gap”...two ways of understanding the concept:
 - Generation Resource Perspective... PJM’s estimate of that generation necessary in 2011 - if the Loudoun and Kemptown lines are not in-service - to reduce loading on the most limiting transmission facility down to 100 %, based on reliability criteria violations identified during RTEP analysis.
 - Load-Serving Perspective... PJM’s estimate of area load at risk; i.e., area load - in excess of area generation - that exceeds an area’s transmission capability to transfer needed power into an area.
- Key Factors impacting Gap:
 - Generation availability
 - Load growth
 - Demand side response

| Scenario | Short Description | Gap Approximations | PJM Assessment |
|----------|--|--|--|
| 1 | October 2007 PJM analysis on 2012 case results without Loudoun (2011) or Kempton (2012) lines | Mid-Atlantic = 6,500 MW Maryland = 1,500 MW | Would require remedial action by PJM. |
| 2 | March 2008 VA results...Gap analysis on updated 2012 PJM RTEP case | Mid-Atlantic = 2,000 - 5,000 MW Maryland = 460 - 1,200 MW | Would require remedial action by PJM. |
| 3 | PJM 2011 case with ONLY that generation and DR that cleared in the 2011/2012 RPM BRA. | Mid-Atlantic = 2,600 – 3,000 MW Maryland = 600 – 690 MW | Would require remedial action by PJM. |
| 4 | PJM 2011 case with all that generation (new AND existing) expected to bid, and that DR forecasted to bid into the 2011/2012 RPM BRA. | Approximately, line loading under limiting reliability criteria test at 99% of facility rating. | Virtually no remaining line loading capability; virtually no reliability margin. |
| 5 | PJM 2011 case with 2011/2012 RPM BRA Gens/DR that cleared + any existing gen that did not clear; (i.e., does not include new generation that did not clear) | Approximately, line loading under limiting reliability criteria test at 100% of facility rating. | No remaining line loading capability; no reliability margin. |

| Scenario | Short Description | Gap Approximations | PJM Assessment |
|----------|---|--|---------------------------------------|
| 1 | October 2007 PJM analysis on 2012 case results without Loudoun (2011) or Kempton (2012) lines | Mid-Atlantic = 6,500 MW Maryland = 1,500 MW | Would require remedial action by PJM. |

Load Growth... January 2007 Forecast for 2007 – 2017 (10-year load growth rates)

- BGE... 1.2%, 7,745 MW in 2011
- PEPCo... 1.4%, 7,439 MW in 2011
- Mid-Atlantic PJM... 1.5%, 63,887 MW in 2011
- Dominion... 1.9%, 20,746 MW in 2011
- PJM RTO... 1.6%, 146,404 MW in 2011

Demand Response... January 2007 Load Forecast

- BGE... 227 MW modeled
- PEPCo... 0 MW modeled
- Mid-Atlantic... 794 MW modeled

Most Limiting Reliability Criteria Violation

- Mt. Storm-Doubs 500 kV line

Generation Highlights

- RTEP07 model.
- Existing generation + that with signed ISAs through January 2007.

Status of Key Generators

- Catoctin - not modeled.
- Benning 15, 16 – not modeled.
- Buzzard (all units) – not modeled.

| Scenario | Short Description | Gap Approximations | PJM Assessment |
|----------|--|--|---------------------------------------|
| 2 | March 2008 VA results...Gap analysis on updated 2012 PJM RTEP case | Mid-Atlantic = 2,000 - 5,000 MW Maryland = 460 - 1,200 MW | Would require remedial action by PJM. |

Load Growth...January 2008 Forecast for 2008 – 2018: (10-year load growth rates...January 2008 vs January 2007)

- BGE... down 0.2% to 1.0%...-119 MW in 2011
- PEPCo... down 0.1% to 1.3%...-104 MW in 2011
- Mid-Atlantic PJM... no change; ...1.5%...+33 MW in 2011
- Dominion... down 0.1% to 1.8%... -208 MW in 2011
- PJM RTO... down 0.1 % to 1.5%... -1,343 MW in 2011

Demand Response... January 2008 Load Forecast

- BGE... 260 MW modeled
- PEPCo... 28 MW modeled
- Mid-Atlantic... 1,018 MW modeled

Most Limiting Reliability Criteria Violation

- Mt Storm-Doubs

Generation Highlights

- RTEP07 2012 model.
- Existing generation + that with signed ISAs as of February 29, 2008

Status of Key Generators

- Catoctin – in model.
- Benning 15, 16 – not modeled.
- Buzzard (all units) – not modeled.
- Indian River 1,2 – not modeled.
- Bergen 2 – not modeled.
- Parlin – in model.
- B. L. England 1, 2, 3 – in model.
- Sewaren 1-4 – in model.

| Scenario | Short Description | Gap Approximations | PJM Assessment |
|----------|---|--|---------------------------------------|
| 3 | PJM 2011 case with ONLY that generation and DR that cleared in the 2011/2012 RPM BRA. | Mid-Atlantic = 2,600 – 3,000 MW Maryland = 600 – 690 MW | Would require remedial action by PJM. |

Load Growth...January 2008 Forecast for 2008 – 2018: (10-year load growth rates...January 2008 vs January 2007)

- BGE... down 0.2% to 1.0%...-119 MW in 2011
- PEPCo... down 0.1% to 1.3%...-104 MW in 2011
- Mid-Atlantic PJM... no change; ...1.5%...+33 MW in 2011
- Dominion... down 0.1% to 1.8%... -208 MW in 2011
- PJM RTO... down 0.1 % to 1.5%... -1,343 MW in 2011

Demand Response

- BGE... 655 MW modeled
- PEPCo... 154 MW modeled
- Mid-Atlantic... 1,635 MW modeled

Most Limiting Reliability Criteria Violation

- Mt. Storm – Doubs 500 kV line

Generation Highlights

- 2011 model.
- All generation (both existing and new) that CLEARED in the 2011/2012 BRA

Status of Key Generators

- Catoctin – not modeled
- Benning (all units) – in model
- Buzzard 15, 16 – in model
- Indian River 1, 2 – not modeled
- Bergen 2 – in model
- B. L. England 1, 2, 3 – in model
- Sewaren 1-4 – in model
- Parlin – in model

| Scenario | Short Description | Gap Approximations | PJM Assessment |
|----------|---|---|--|
| 4 | PJM 2011 case with all that generation (new AND existing) expected to bid, and that DR forecasted to bid into the 2011/2012 RPM BRA. | Approximately, line loading under limiting reliability criteria test at 99% of facility rating. | Virtually no remaining line loading capability; virtually no reliability margin. |

Load Growth...January 2008 Forecast for 2008 – 2018:

(10-year load growth rates...January 2008 vs January 2007)

- BGE... down 0.2% to 1.0%...-119 MW in 2011
- PEPCo... down 0.1% to 1.3%...-104 MW in 2011
- Mid-Atlantic PJM... no change; ...1.5%...+33 MW in 2011
- Dominion... down 0.1% to 1.8%... -208 MW in 2011
- PJM RTO... down 0.1 % to 1.5%... -1,343 MW in 2011

Demand Response... January 2008 Load Forecast

- BGE... 260 MW modeled
- PEPCo... 28 MW modeled
- Mid-Atlantic... 1,018 MW modeled

Most Limiting Reliability Criteria Violation

- Mt Storm – Doubs 500 kV Line
(line loading at 99% of rating)

Generation Highlights

- 2011 model.
- All generation – new AND existing – expected to bid into the 2011/2012 RPM BRA.

Status of Key Generators

- Catoctin – not modeled
- Benning (all units) – in model
- Buzzard 15, 16 – in model
- Indian River 1, 2 – not modeled
- Bergen 2 – in model
- B. L. England 1, 2, 3 – in model
- Sewaren 1-4 – in model
- Parlin – in model

| Scenario | Short Description | Gap Approximations | PJM Assessment |
|----------|--|--|--|
| 5 | PJM 2011 case with 2011/2012 RPM BRA Gens/DR that <u>cleared + any existing gen that did not clear</u> ; (i.e., does not include new generation that did not clear) | Approximately, line loading under limiting reliability criteria test at 100% of facility rating. | No remaining line loading capability; no reliability margin. |

Load Growth...January 2008 Forecast for 2008 – 2018:

(10-year load growth rates...January 2008 vs January 2007)

- BGE... down 0.2% to 1.0%...-119 MW in 2011
- PEPCo... down 0.1% to 1.3%...-104 MW in 2011
- Mid-Atlantic PJM... no change; ...1.5%...+33 MW in 2011
- Dominion... down 0.1% to 1.8%... -208 MW in 2011
- PJM RTO... down 0.1 % to 1.5%... -1,343 MW in 2011

Demand Response

- BGE... 655 MW modeled
- PEPCo... 154 MW modeled
- Mid-Atlantic... 1,635 MW modeled

Most Limiting Reliability Criteria Violation

- Mt Storm – Doubs 500 kV Line
(line loading at 100% of rating)

Generation Highlights

- 2011 model.
- Generation (both existing and new) that CLEARED in the 2011/2012 BRA + that existing gen that did not clear

Status of Key Generators

- Catoctin – not modeled
- Benning (all units) – in model
- Buzzard 15, 16 – in model
- Indian River 1, 2 – not modeled
- Bergen 2 – in model
- B. L. England 1, 2, 3 – in model
- Sewaren 1-4 – in model
- Parlin – in model

- Absent lines, options include:
 - Incremental enhancements with 1 to 3 years needed
 - Upgrades to lower voltage facilities
 - Flexible AC flow shifting control devices & other new technologies
 - Incremental RPM auction concept under consideration for planning parameter changes (i.e., proposed lines delayed)
 - Reliability Must Run contracts on requested deactivations
 - Operating procedures / system reconfigurations to minimize risk

- Options depend on several factors:
 - Length of line delay
 - Available time to implement incremental transmission enhancements
 - Expected generation availability
 - Expected demand response over delay period
 - Expected load over delay period; impacts of slowing US/regional economy and how it rebounds



Status of Major Upgrades in BGE and PEPCo

| Location | Equipment | Upgrade Description | Projected Completion Date |
|--|-----------------|--|---------------------------|
| Palmers Corner - Blue Plains | Circuits | Two new 230kV circuits | In-service |
| Waugh Chapel | Capacitor Bank | Install Waugh Chapel 230kV 360MVAR capacitor bank | In-service |
| Various Substations, 138 kV and below | Capacitor Banks | Add 275+ MVAR of capacitors on underlying system, 138 kV and below. | In-service |
| Doubs - Dickerson and Doubs - Aqueduct - Dickerson | Lines | Upgrade 230kV lines to 1200MVA | 5/2009 |
| Waugh Chapel | Transformer | Add 4th 500/230kV transformer in a new 500kV transformer bay. Operate the existing in-service spare transformer on standby and other associated configuration changes. | 6/2009 |
| Brighton Substation | Transformer | Add 2nd 1000 MVA 500/230kV transformer; 2, 500kV circuit breakers and miscellaneous bus work | 6/2009 |
| Conastone | Transformer | Upgrade both 500/230kV transformer banks with larger transformers, replace breakers #4 & #7 and other configuration changes | 5/2009 |
| Burches Hill | Transformer | Burches Hill Substation - Add 2nd 1000 MVA 500/230kV Transformer | 6/2011 |
| Bells Mill | Capacitor | Add 100 MVAR of reactive capability. | 6/2010 |
| Bells Mill | Capacitor | Add 100 MVAR of reactive capability. | 6/2010 |
| Mt. Storm - 502 Junction | Circuit | Build new 500 kV line. | 6/2011 |
| Doubs | Transformer | Replace Transformer #2. | 5/2011 |
| Doubs | Transformer | Replace Transformer #3. | 12/2010 |
| Doubs | Transformer | Replace Transformer #4. | 6/2010 |



Status of Major Upgrades in BGE and PEPCo, continued...

| Location | Equipment | Upgrade Description | Projected Completion Date |
|-------------------------------|--|--|---------------------------|
| Dickerson - Pleasant View | Circuit | Reconductor 230kV line. | 6/2011 |
| Dickerson - Pleasant View | Circuit | Reconductor 230kV line. | 6/2011 |
| Brighton | Transformer | Replace existing 500/230 kV transformer at Brighton | 6/2012 |
| Conastone and Graceton | Second Circuit and Circuit Breaker | Install a second Conastone - Graceton 230 kV circuit and replace Conastone 230 kV breaker 2323/2302 | 6/2012 |
| Burches Hill | Transformer | Install third Burches Hill 500/230 kV transformer | 6/2012 |
| Ritchie & Benning Sta. "A" | Circuits | Two new 230 kV circuits between Ritchie - Benning Sta. "A" | 6/2012 |
| Bedington - Kemptown | Circuit | Bedington to Kemptown 500 kV lines (twin circuit) and associated 765/500 kV terminal upgrades at Bedington and 500 kV station establishment at Kemptown -- (APS portion) | 6/2012 |
| Possom Point - Calvert Cliffs | New transmission line and associated equipment | MAPP Project Phase 1: install new Possum Point to Calvert Cliffs 500 kV | 6/2013 |
| Possom Point - Calvert Cliffs | New transmission line and associated equipment | MAPP Project Phase 1: install new Possum Point to Calvert Cliffs 500 kV | 6/2013 |
| Calvert Cliffs - Salem | New transmission line and associated equipment | MAPP Project Phase 2: install new Calvert Cliffs - Salem 500 kV | 6/2013 |
| Calvert Cliffs - Salem | New transmission line and associated equipment | MAPP Project Phase 2: install new Calvert Cliffs - Salem 500 kV | 6/2013 |