

**PJM Outage Acceleration Program**  
**Outages scheduled for March 2007**

There are six (7) outages scheduled in March 2007 that meet the three day, \$500,000 FTR revenue inadequacy criteria required for inclusion in the PJM Outage Acceleration Program. The six (7) outages that are projected to contribute to FTR revenue inadequacy and the projected revenue inadequacy are:

<b>Ticket No:</b>	<b>Comp</b>	<b>Start Date</b>	<b>End Date</b>	<b>Duration</b>	<b>Station</b>	<b>Voltage</b>	<b>Equipment Name</b>	<b>Projected Revenue Inadequacy</b>
135416	PE	3/19/2007	3/23/2007	4.33	ELROY	500 KV	ELR-WHI	\$15,410,504
					WHITPAIN	500 KV	WHT 3TR	
135409	PE	3/10/2007	3/15/2007	5.33	WHITPAIN	500 KV	WHT 2TR	\$6,320,935
					LIMERICK	500 KV	LIM-WHI1	
169177	AEP	3/5/2007	4/20/2007	46.29	KAMMER2	765 KV	KAM-SCA1	\$3,824,706
133259	PE	3/19/2007	3/23/2007	4.33	BRADFORD	230 KV	BRA-NEW2	\$1,176,596
172407	PL	3/12/2007	4/27/2007	45.96	BERKS	230 KV	BER-SAK	\$1,014,927
135418	PE	3/19/2007	3/23/2007	4.33	EMILIE	138 KV	EMI-NES	\$847,248
171215	DOM	3/5/2007	3/14/2007	9.38	ENDCAVRN	230 KV	2017B	\$725,707
					ENDCAVRN	230 KV	TX3	

The projected revenue inadequacy does not consider the impact of operating actions that have not yet been identified but may be developed and employed to reduce the required off cost generation during any of the above outages. Any market participant may submit a request prior to the Close of Business on 01/23/07 to fund the incremental cost associated with reducing the market impact of any of the above outages by contacting PJM's OASIS hotline at (610) 666-8972 or e-mail address [oasisadmin@pjm.com](mailto:oasisadmin@pjm.com)