

Crawford Units 31, 32 & 33 Retirements

General

PJM has analyzed the impact of the announced retirement of the Crawford Units 31, 32 and 33. The total generation for these units is 176 MWs with a requested retirement date of prior to the summer of 2005. This document summarizes the reliability analysis for the retirement of these generators.

Network Impacts

The 2005 summer system was studied to determine compliance with applicable reliability criteria. There were no identified problems for the retirement of these units.