



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts - 10MW Injection at North Bangor

Potential network impacts for an increase of 10 MW injected at North Bangor 34.5kV substation were evaluated. No system reinforcement requirements were identified for the additional 10 MW.