



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

Network Impacts - 25MW Injection at Titusville

Potential network impacts for an increase of 25 MW injected at Titusville 34.5kV substation were evaluated. No system reinforcement requirements were identified for the additional 25 MW.