



Generation Interconnections

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as an Energy-Only resource.

Network Impacts - 8MW Injection

Network Impacts - 8MW Injection

Injection of 8 MW into the Bayview 26kV substation was evaluated for network impacts. The following network impacts were identified:

Normal System

- No identified problems

Tower Line Outages (MAAC Criteria IIC)

- No identified problems.

Generator Deliverability

- No identified problems.

Short Circuit Analysis

- No identified problems