

# Generation Interconnection

This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a capacity resource.

## Network Impacts -51.6 MW Injection into the Frackville 69kV substation (G34)

### Network Impacts

Potential network impacts for the injection of 51.6 MW into the Hauto-Frackville #3 69kV line were evaluated for summer peak conditions in 2005.

A summary of the results follows:

### Normal System

- No identified problems.

### Multiple Facility Contingency (MAAC Criteria IIC)

- No identified problems.

### Generator Deliverability

- No identified problems.

### Short Circuit Analysis

Short circuit analysis was performed in the area of the new G34 generation. Analysis indicates that the existing 69 kV fuses at Altamont substation will be over-dutied. The estimated cost to replace the fuses is \$26,000.

Northeast PA dynamic system stability tests (MAAC Section IV) will be conducted during the Impact Study. Stability studies have not been conducted as part of this Feasibility Study.

### Cost

The cost for interconnecting this generating facility consists of the direct connection requirements of \$522,000 and the network requirements to replace fuses at Altamont for \$26,000. The total cost to interconnect this project is \$548,000.