

## **Generation Interconnection**

**This analysis was completed to assess the reliability impact for a new generator interconnecting to the PJM system as a Capacity resource.**

### **Network Impacts - 10 MW Capacity Injection**

Network impacts for the Capacity injection of 10 MW into the Edgemoor 230kV bus was evaluated. No network impacts were identified.