

**Network Impacts**

The #K24 project was studied as a **30 MW** status change from energy to capacity to determine compliance with reliability criteria for summer peak conditions in 2007. Potential network impacts were as follows:

**Generator Deliverability**

No identified problems.

**Contribution to Previously Identified System Reinforcements**

None.