

# **PJM Generator Interconnection Request**

## **Feasibility / Impact Study Report**

**Queue #R15**

**Adkins 345 kV**

**(Darby Generating Units)**

**9 MW**

**(Increase in existing capacity)**

**March 2007**

**DOCS#: 411030**

## **R15 Adkins 345 kV (Darby Generating Units)**

### **Feasibility / Impact Study Report**


#### **General**

DPL Energy Inc. has requested to interconnect an additional 9 MWs of Generation Capacity at Adkins 345 kV bus. This additional generation is an increase to the Darby Generating Station Units #1, #3, #5, and #6 output capacity. The additional 9 MW of generation capacity is divided as follows: Darby 1 (3 MW increase); Darby 3 (1 MW increase); Darby 5 (3 MW increase); Darby 6 (2 MW increase). The increased capacity of each unit is already available and has been demonstrated. The Darby Generating Station is located in Mt. Sterling, Ohio. PJM has assigned this project queue #R15 Adkins 345 kV.

#### **Direct Connection**

The Darby Generating Units are connected to Adkins 345 kV bus as shown on the following one-line diagram (next page). No additional facilities are required.

**SINGLE-LINE DIAGRAM**  
**R15 Adkins 345 kV (Darby Generating Units)**



## **Network Impacts**

The #R15 project was studied as a 9 MW increase in Capacity to the existing generating facility at Adkins 345 kV. Project #R15 was evaluated for compliance with reliability criteria for summer peak conditions in 2011. Potential network impacts were as follows:

### **Generator Deliverability**

No problems were identified

### **Multiple Facility Contingency**

No problems were identified

### **Contribution to Previously Identified Overloads**

None

### **New System Reinforcements**

None

### **Contribution to Previously Identified System Reinforcements**

None

### **Short Circuit**

Not required. There is no change to the electrical characteristics of the units or the GSU.

### **Stability**

Not required as the increase in capacity request is for less than 30 MW.