

PJM Generator Interconnection
U1-093 Ladysmith 230-kV (20 MW Energy)
Feasibility Study

July 2008
DMS #491989

Introduction

This Feasibility Study has been prepared in accordance with the PJM Open Access Transmission Tariff, §36.2, as well as the Feasibility Study Agreement between Interconnection Customer (IC) and PJM Interconnection, LLC (PJM) (Transmission Provider).

Preface

The intent of the feasibility study is to determine a plan, with preliminary cost and construction time estimates, to connect the subject generation interconnection project to the PJM network at a location specified by the Interconnection Customer. As a requirement for interconnection, the Interconnection Customer may be responsible for the cost of constructing Network Upgrades, which are facility additions, or upgrades to existing facilities, that are needed to maintain the reliability of the PJM system. All facilities required for interconnection of a generation interconnection project must be designed to meet the technical specifications for the appropriate transmission owner.

In some instances an interconnection customer may not be responsible for 100% of the identified network upgrade cost because other transmission network uses, e.g. another generation interconnection or merchant transmission upgrade, may also contribute to the need for the same network reinforcement. The possibility of sharing the reinforcement costs with other projects may be identified in the feasibility study, but the actual allocation will be deferred until the impact study is performed.

The Feasibility Study estimates do not include the feasibility, cost, or time required to obtain property rights and permits for construction of the required facilities. The project developer is responsible for the right of way, real estate, and construction permit issues. For properties currently owned by Transmission Owners, the costs may be included in the study.

Potential Network Impacts

PJM queue project U1-093 was studied as a 20MW energy injection at the Ladysmith 230-kV substation in the DVP area. U1-093 was evaluated for compliance with reliability criteria for summer peak conditions in 2012. Potential network impacts were as follows:

Generator Deliverability

(Single or N-1 contingencies for the Capacity portion only of the interconnection)

None

Multiple Facility Contingency

(Double Circuit Tower Line, Line with Failed Breaker and Bus Fault contingencies for the full energy output)

None

Short Circuit

(Summary form of Cost allocation for breakers will be inserted here if any)

None

Contribution to Previously Identified Overloads

(This project contributes to the following contingency overloads, i.e. "Network Impacts", identified for earlier generation or transmission interconnection projects in the PJM Queue)

None

New System Reinforcements

(Upgrades required to mitigate reliability criteria violations, i.e. Network Impacts, initially caused by the addition of this project generation)

None

Contribution to Previously Identified System Reinforcements

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)
(Summary form of Cost allocation for transmission lines and transformers will be inserted here if any)*

None

Dominion Analysis

Dominion concurs with the PJM results for this Feasibility Study. Dominion and PJM will need to perform System Impact Study load flow and stability analysis with the aggregate energy output for queues U1-093, 94 and 95.

Attachment Facilities

Since the proposed generation addition is an increase to a previously queued project no new attachment facilities are required.