

## **W1-038 Fair Lawn 138kV**

### **Generation Interconnection**

#### **Network Impacts**

Queue project W1-038 was studied as a(n) 10.0MW ( 10.0MW of which was Capacity) injection into PSE&G's system at the Fair Lawn 26.4kV substation. The project was studied on a combined Feasibility/Impact basis which utilizes an AC analysis and incorporates all contingency types. Project W1-038 was evaluated for compliance with reliability criteria for summer peak conditions in 2014. Potential network impacts were as follows:

#### **Generator Deliverability**

*(Single or N-1 contingencies for the Capacity portion only of the interconnection)*

No problems identified

#### **Multiple Facility Contingency**

*(Double Circuit Tower Line, Line with Failed Breaker and Bus Fault contingencies for the full energy output)*

No problems identified

#### **Short Circuit**

*(Summary form of Cost allocation for breakers will be inserted here if any)*

Not required since the generator constants did not change.

#### **System Reinforcements**

None.

#### **Contribution to Previously Identified System Reinforcements**

*(Overloads initially caused by prior Queue positions with additional contribution to overloading by this project. This project may have a % allocation cost responsibility which will be calculated and reported for the Impact Study)*

None.