

Manual 22

“Generator Resource Performance Indices” Redline Changes



Jerry Bell
Senior Lead Engineer
Resource Adequacy Planning
Markets & Reliability Meeting
January 26th, 2017

- Revisions proposed as result of periodic review:
 - Revisions needed to clean-up outdated language and ensure language follows current processes
 - Minor revisions needed to correct grammar, spelling, punctuation, consistency of terms, and document references
- Revisions needed to introduce EFDH, EMDH and EPDH to replace EFPOH, EMPOH and EPPOH

- Replacing antiquated terms
 - Introducing derated hours to replace partial outage hours
 - EFDH – Equivalent Forced Derated Hours
 - Replacing EFPOH, Equivalent Forced Partial Outage Hours
 - EMDH – Equivalent Maintenance Derated Hours
 - Replacing EMPOH, Equivalent Maintenance Partial Outage Hours
 - EPDH – Equivalent Planned Derated Hours
 - Replacing EPPOH, Equivalent Planned Partial Outage Hours
 - Correct formatting for $EFOR_D$ to $EFOR_d$

- Planning Committee first read (redline) – 1/12/2017
- Markets & Reliability Committee first read (redline) – 1/26/2017
- Planning Committee endorsement – 2/9/2017
- Markets & Reliability Committee endorsement – 2/23/2017
- Implementation Date – 4/1/2017