



Operations Assessment Task Force 2010-2011 Winter Study Results

PJM Operating Committee
Nancy Huang
Nov. 16, 2010

- Case Parameters
- 50/50 Non-Diversified Peak Load Study Results

- Load
 - LAS Forecast: 117,542 MW
 - Case Load: 117,908 MW
 - RTO Net Interchange: Exporting 2219 MW
- PJM RTO Installed Capacity
 - 165,933 MW
- Discrete Outages
 - 13,602 MW

- No reliability problems identified
- Off-cost and switching used to control overloads and voltage violations

Questions?