



# Light Load Operational Performance


Paul McGlynn  
PJM Planning Committee  
5/12/10

- Most of PJM's thermal and reactive criteria specifies testing to be done at peak load to ensure deliverability of capacity
- PJM Planning and Operation staff routinely review operating issues and develop upgrades as required to mitigate issues
  - PCLLRWs
  - TLR (level 3 for 1000 hours or 100 occurrences)
  - High Voltage Issues
- **Emerging issues over the midnight period:**
  - High Voltage – could be aggravated by new transmission
  - Thermal problems – pumped storage and renewable integration
- Do we need a criteria related to delivery of energy?


# New Renewable Capacity Required due to RPS

Year	New RPS MW needed assuming a 30% CF for existing and future renewable generation
2009	-4,944
<b>2010</b>	<b>-2,000</b>
2011	1,295
2012	3,845
2013	6,175
2014	8,675
<b>2015</b>	<b>11,802</b>
2016	15,525
2017	18,093
2018	21,932
2019	24,664
<b>2020</b>	<b>28,497</b>
2021	31,602
2022	35,161
2023	36,904
2024	38,779
<b>2025</b>	<b>40,636</b>

## New RPS Nameplate MW needed due to RPS



## Comparison of Average Hourly Load vs Average Wind Generation



- What load levels should be studied?
  - Shoulder Peak (i.e. 70% summer peak 50/50)?
  - Off peak?
  - Others?
- How should we set up the generation dispatch?
  - Pump storage pumping
  - Base load on at full
  - Wind generation dispatch
- What interchange should be used?
  - Bias from areas with high wind penetration