



# Queue Process Challenges

## <\$5M Queue Cost Allocation & Alternate Queue



Aaron Berner  
Manager, Interconnection Analysis  
Planning Committee  
April 13, 2017

- Current studies performed
  - Feasibility Study
- Problems with current process
  - “Screen” criteria requires queue to be closed (6 month queue)
    - Evaluation of “screen” criteria requires load flow studies with all projects in queue modeled

- Solution
  - Remove alternate queue screening
- Remove Alternate Queue screening
  - Allow projects to be evaluated for impacts once Point of Interconnection (POI) has been established
    - Identification of impacts could proceed with known POI if all previously queued projects in vicinity of project under study are also known

- Reinforcement costs <\$5 million allocated to all projects in a queue which add load to the violation defining the need for the reinforcement
- Problems with current process
  - Criteria requires queue to be closed (6 month queue)

- Solution
  - Evaluate need for reinforcements with first request to cause the need for a reinforcement to be allocated 100% of the cost of the upgrade
    - Subsequent projects which contribute to the need for the reinforcement would have cost allocation based on MW impacts

- Endorsement at May PC
- First read at MRC in May