

The background of the slide is a photograph of a large, white, lattice-structured transmission tower against a clear blue sky. Power lines are visible extending from the tower across the frame. The tower is the central focus of the image.

Transmission Expansion Advisory Committee Meeting

2011 Market Efficiency Analysis Results

September 8, 2011

- 2010 project review updates
 - COMED Area
 - PPL, METED, and PENELEC Area
 - Dominion and AEP Areas



Market Efficiency Projects

COMED AREA



2011 Market Efficiency Analysis Results

COMED Area Proposed Projects

Project Number	Description	Expected ISD	Voltage	Estimated Costs (\$ millions)	Benefit/Cost
MEP-A-1	Byron-Cherry Valley-Pleasant Valley 345 KV	2016	345	112.5	0.75
MEP-A-2	Byron-Pleasant Valley 345 KV	2016	345	105	0.96
MEP-A-3	Cherry Valley - Pleasant Valley 345 KV	2016	345	67.5	2.74
MEP-A-4	Byron - Charter Grove- Wayne 345 KV, Charter Grove 345/138 KV TX.	2016	345	275	0.24
MEP-A-5	Byron - Wayne 345 KV	2016	345	175	0.41

MEP-A-3 project moves congestion to Byron-Cherry Valley 345 KV Ckt.



Summary COMED Area Proposed Upgrades


- Next Steps
 - Independent Cost Review currently being conducted
 - Coordination with Light Load study
 - Coordination with Regional Planning Process Task Force (RPPTF) developments



Market Efficiency Projects

METED, PPL, PENELEC Area

- Project MEP-B-6: Hunterstown – Jackson
 - New Single 230 KV circuit from Hunterstown to Jackson
 - New transformer at Hunterstown 500/230 KV.
- Project creates reliability and market concerns on lower voltage system
 - Hunterstown 230/115 KV transformer
- Modified project to add additional 230/115 KV transformer at Hunterstown.
- Expected ISD: 6/1/2016
- Estimated project Costs.
 - \$75 million
- Results:
 - Benefit/Cost ratio=.85
 - **.85 < 1.25 - Fail**



METED, PPL, PENELEC Area Proposed Projects

Project Number	Description	Expected ISD	Voltage	Estimated Costs (\$ millions)	Benefit/Cost
MEP-A-6	New Hunterstown 500 kV Tx, New single circuit Hunterstown-Conewago 230 kV line, New Conewago 230 kV substation connecting the Jackson - Three Mile Island 230 kV and West Shore - Brunner Island 230 kV transmission lines near their intersection in York County	2016	230	99.4	1.09
MEP-A-7	Two new Hunterstown 500 kV Tx, New Double circuit Hunterstown-Conewago 230 kV line, New Conewago 230 kV substation connecting the Jackson - Three Mile Island 230 kV and West Shore - Brunner Island 230 kV transmission lines near their intersection in York County	2016	230	134.1	0.74
MEP-A-8	New 230 kV transmission line from Keystone to Shawville	2015	230	137.5	0.34
MEP-B-6	New 500/230 Transformer at Hunterstown with a new Hunterstown to Jackson 230 kV circuit plus a new 230/115 transformer at Hunterstown.	2016	230	75	0.85



Summary METED, PPL, PENELEC Area Proposed Upgrades


- Next Steps
 - Independent Cost Review currently being conducted




Market Efficiency Projects

Dominion and AEP Area


- Project MEP-B-1
- Install a 765/500 kV transformer at Joshua Falls station and construct an approximately 85-mile 500 kV line from Joshua Falls station to the existing Doods - Elmont 500 kV line. Construct an approximately 30-mile 500 kV line from the Doods - Elmont 500 kV line to Ladysmith station. Split the Doods - Elmont 500 kV line to create separate Joshua Falls - Elmont and Doods - Ladysmith 500 kV circuits.
- Expected ISD: 6/1/2017
- Estimated project Costs.
 - \$300 million
- Results:
 - Benefit/Cost ratio= -.13
 - **-.13 < 1.25 - Fail**




- Project MEP-B-2
- Install a 765/500 kV transformer at Joshua Falls station and construct a new 500 kV station on the existing Dooks - Elmont 500 kV line. Construct an approximately 85-mile 500 kV line from Joshua Falls station to the new station. Construct an approximately 30-mile 500 kV line from the new station to Ladysmith station
- Expected ISD: 6/1/2017
- Estimated project Costs.
 - \$330 million
- Results:
 - Benefit/Cost ratio= -.13
 - **-.13 < 1.25 - Fail**




- Project MEP-B-3
- Install a 765/500 kV transformer at Joshua Falls station and construct an approximately 50-mile 500 kV line from Joshua Falls station to Clover station.
- Expected ISD: 6/1/2017
- Estimated project Costs.
 - \$170 million
- Results:
 - Benefit/Cost ratio= $-.07$
 - $-.07 < 1.25$ - Fail



- Project MEP-B-4 (MEP-B-1/MEP-B-3)
- Install a 765/500 kV transformer at Joshua Falls station and construct an approximately 85-mile 500 kV line from Joshua Falls station to the existing Dooks - Elmont 500 kV line. Construct an approximately 30-mile 500 kV line from the Dooks - Elmont 500 kV line to Ladysmith station. Split the Dooks - Elmont 500 kV line to create separate Joshua Falls - Elmont and Dooks - Ladysmith 500 kV circuits.
- Install a 765/500 kV transformer at Joshua Falls station and construct an approximately 50-mile 500 kV line from Joshua Falls station to Clover station
- Expected ISD: 6/1/2017
- Estimated project Costs.
 - \$410 million
- Results:
 - Benefit/Cost ratio= -.03
 - **-.03 < 1.25 - Fail**




- Project MEP-B-5 (MEP-B-2/MEP-B-3)
- Install a 765/500 kV transformer at Joshua Falls station and construct a new 500 kV station on the existing Dooks - Elmont 500 kV line. Construct an approximately 85-mile 500 kV line from Joshua Falls station to the new station. Construct an approximately 30-mile 500 kV line from the new station to Ladysmith station.
- Install a 765/500 kV transformer at Joshua Falls station and construct an approximately 50-mile 500 kV line from Joshua Falls station to Clover station
- Expected ISD: 6/1/2017
- Estimated project Costs.
 - \$440 million
- Results:
 - Benefit/Cost ratio= -.25
 - **-.25 < 1.25 - Fail**




- Project MEP-B-7
- Install a 765/500 kV transformer at Joshua Falls station and construct a 500 kV line from Joshua Falls to Cunningham Station.


- Expected ISD: 6/1/2017
- Estimated project Costs.
 - \$375 million
- Results:
 - Benefit/Cost ratio= .01
 - **.01 < 1.25 - Fail**




- Project MEP-B-8
- Install a 765/230 kV transformer at Joshua Falls Station and construct a 230 kV line from Joshua Falls to Midlothian Station via Buckingham Station.
- Expected ISD: 6/1/2017
- Estimated project Costs.
 - \$220 million
- Results:
 - Benefit/Cost ratio= 1.07
 - 1.07 < 1.25 - Fail



- Project MEP-B-9
- Install a 765/230 kV transformer at Joshua Falls station and construct a 230 kV double circuit line from Joshua Falls to Midlothian station via Buckingham Station.
- Expected ISD: 6/1/2017
- Estimated project Costs.
 - \$280 million
- Results:
 - Benefit/Cost ratio= 1.88
 - 1.88 > 1.25 - Pass



- Project MEP-B-10
- Install a 765/345kV transformer at Joshua Falls Station, Install a new 500/345 kV transformer at both Doods and Morrisville stations. Construct an approximately 133-mile 345 kV line from Joshua Falls to Doods to Morrisville stations.
- Expected ISD: 6/1/2017
- Estimated project Costs.
 - \$533 million
- Results:
 - Benefit/Cost ratio= 1.68
 - 1.68 >1.25 - Pass





2011 Market Efficiency Analysis Results

Dominion and AEP Area Proposed Upgrades (Table 1 of 2)

Project Number	Description	Expected ISD	Voltage	Estimated Costs (\$ millions)	Benefit/Cost	15 year Net Present Value of Benefit (\$ millions)	Below 500 KV Method 15 year Net Present Value of Benefit (\$ millions)
MEP-A-9	Install a 500/345 kV transformer at Bath County station and construct a 345 kV line from Kanawha River station to Bath County station.	2017	345	\$260.5	4.03	\$1,639.1	-
MEP-A-10	Install two 500/345 kV transformers at Bath County station and construct 345 kV line from Kanawha River station to Bath County station.	2017	345	\$275	4.36	\$1,869.6	-
MEP-A-11	Install two 500/345 kV transformers at Bath County station and construct a double circuit 345 kV line from Kanawha River station to Bath County station.	2017	345	\$386.2	3.90	\$2,349.1	-
MEP-B-1	Install a 765/500 kV transformer at Joshua Falls station and construct an approximately 85-mile 500 kV line from Joshua Falls station to the existing Doods - Elmont 500 kV line. Construct an approximately 30-mile 500 kV line from the Doods - Elmont 500 kV line to Ladysmith station. Split the Doods - Elmont 500 kV line to create separate Joshua Falls - Elmont and Doods - Ladysmith 500 kV circuits.	2017	500	\$300	(0.13)	(\$61.0)	\$956.1
MEP-B-2	Install a 765/500 kV transformer at Joshua Falls station and construct a new 500 kV station on the existing Doods - Elmont 500 kV line. Construct an approximately 85-mile 500 kV line from Joshua Falls station to the new station. Construct an approximately 30-mile 500 kV line from the new station to Ladysmith station.	2017	500	\$330	(0.13)	(\$66.8)	\$1,024.7
MEP-B-3	Install a 765/500 kV transformer at Joshua Falls station and construct an approximately 50-mile 500 kV line from Joshua Falls station to Clover station.	2017	500	\$170	(0.07)	(\$17.3)	\$349.5



2011 Market Efficiency Analysis Results

Dominion and AEP Area Proposed Upgrades (Table 2 of 2)

Project Number	Description	Expected ISD	Voltage	Estimated Costs (\$ millions)	Benefit/Cost	15 year Net Present Value of Benefit (\$ millions)	Below 500 KV Method 15 year Net Present Value of Benefit (\$ millions)
MEP-B-4	Project MEP-B-1 and MEP-B-3	2017	500	\$410	(0.03)	(\$18)	\$971.9
MEP-B-5	Project MEP-B-2 and MEP-B-3	2017	500	\$440	(0.25)	(\$173)	\$897.1
MEP-B-7	Install a 765/500 kV transformer at Joshua Falls station and construct a 500 kV line from Joshua Falls to Cunningham Station.	2017	500	\$375	0.01	\$3.2	\$393.2
MEP-B-8	Install a 765/230 kV transformer at Joshua Falls Station and construct a 230 kV line from Joshua Falls to Midlothian Station via Buckingham Station.	2017	230	\$220	1.07	\$366.5	-
MEP-B-9	Install a 765/230 kV transformer at Joshua Falls station and construct a 230 kV double circuit line from Joshua Falls to Midlothian station via Buckingham Station.	2017	230	\$280	1.88	\$822.4	-
MEP-B-10	Install a 765/345kV transformer at Joshua Falls Station, Install a new 500/345 kV transformer at both Dooms and Morrisville stations. Construct an approximately 133-mile 345 kV line from Joshua Falls to Dooms to Morrisville stations.	2017	345	\$533	1.68	\$1,395.4	-



Dominion and AEP Area Proposed Upgrades Summary

- Several Projects show Large Market Benefits
- Benefit calculated different depending on type of project.

$$\text{Annual Benefit} = (.7)(\Delta \text{ System Production Cost}) + (.3)(\Delta \text{ Load Energy Payment})$$

- Δ System Production Cost is change in system generation variable cost (fuel costs, variable O&M costs and emissions costs) associated with total PJM energy production
- Δ Load Energy Payment is change in net load energy payment (change in gross load payment minus change in transmission right credit)
 - For projects that have costs allocated regionally (500 kV and up), the load energy payment for all PJM zones is considered
 - For projects that have costs allocated using a flow-based methodology (below 500 kV) , the load energy payment for only those PJM zones that show a decrease in load energy payment is considered.
- Proposed Market Efficiency Regional Projects difficult to pass 1.25 Benefit/Cost Threshold
 - Projects that provide large Net Benefits may be dismissed because of type of project (Regional vs. below 500 KV)
 - Consider changing calculation for regional to be same as below 500 KV projects.
 - Zones in which project shows no load benefit or increase in net load energy payments have no cost allocation
 - Zones in which project shows load benefit or decrease in net load energy payments will have a cost allocation



Summary Dominion/AEP Area Proposed Upgrades

- Next Steps
 - Independent Cost Review currently being conducted
 - Incorporate pending reliability baseline projects
 - Rerun Studies as appropriate
 - Reliability Analysis review for all passing projects
 - Sensitivity analysis for Key input assumptions
 - Variations to be considered