



Load Management Task Force Load Management Retest exception

LMTF
April 8, 2010



Impact of proposed changes on current rules

	Proposed changes	Rules impacted by change
	Allow CSP to not Retest every resource that fails (resource will maintain test result) if PJM notified in advance	OATT, attachment DD (~sheet 625) Manual 18, 8.6

- CSPs are currently able to “retest” only Resources that did not perform if Zonal portfolio performance greater than 75%
 - CSP retesting a subset of Resources must retest all Resources in the Zone that didn’t fully comply or be viewed as 0% compliant.
 - Example: Zonal performance = 80% and a CSP chose to retest
 - 20 Resources in zonal portfolio where each performed <100%
 - 1 resource performance = 99%
 - CSP must retest all 20 resources even if willing to live with 99% performance for one resource and prefer to test only 19 resources in retest.
- Recommend the retest provision eliminate the requirement to include ALL Resources if the CSP:
 - explicitly notifies PJM in advance of a retest exactly which Resources will not be retested AND
 - Resource performance test result >95%