



Working to Perfect the Flow of Energy

Reserve Calculations

- Synchronized Reserve (a.k.a. Spinning Reserve)
 - Increase in output energy level of a synchronized generator which can be attained in **10 min.**
 - Or decrease in a Load Response Resource
 - Max energy output achieved in 10 min by a unit operating as a synchronous condenser
 - Maintained in real-time via Synchronized Reserve Market
- Quick-start Reserve
 - Not synchronized to system
 - Includes maximum energy output level of a unit that can be attained in **10 min.** from the PJM request
 - Generally run-of-river hydro, combustion turbines, combined cycle and diesel type units


- **Primary Reserve (a.k.a. Contingency Reserve)**
 - Synchronized Reserve + Quick Start Reserve
 - All MW available within 10 minutes
- **Secondary Reserve (a.k.a. Supplemental Reserve)**
 - The reserve capability that can be fully converted into energy in **>10 to 30 minute** interval following a request by PJM
 - Equipment does not need to be synchronized to the system

- Day-ahead Scheduling Reserve (a.k.a. Operating Reserve)
 - Generation available from either offline or online units within **30 minutes**
 - Scheduled to meet Operating Reserve requirements in DA Market and Reserve Adequacy (RA) Run
 - Market for Day-ahead Scheduling Reserve began 6/1/08
 - Not required to be maintained in real-time
 - Primary Reserve + Secondary Reserve

- The following are NOT included in the current EMS or Tier 1 reserve calculations:
 - Pumped Storage in pumping mode (monitored separately)
 - Nuclear Units
 - Wind Units
 - Units logged as “Testing”, “Failed to Start”, “Tripped” or “Unavailable”
 - Online CTs that are generating
 - For CTs, only condensing units are included in reserve calculations
 - Demand Response Resources
 - Included in Tier 2 Synchronized Reserve and DA Scheduling Reserve Market
 - Reserves from implementation of Emergency Procedures
 - i.e. Max Emergency, Voltage Reduction, Interchange curtailments, Public Appeal for reduction, Shared Reserve Agreements

- The reserve calculations depend on accurate generation data in the following areas
 - Unit Limits
 - Specifically the Synchronized Max and Economic Max Limits
 - Ramp rates
 - Specifically the Synchronized Reserve Ramp Rate
 - Notification Time
 - Start-up Time
 - Ambient temperature adjusted limits

- The following Reserve categories will be eliminated:
 - Normal Regulating Reserve
 - Beyond Secondary
- The following Reserve categories will be consolidated into Synchronized Reserve:
 - Synchronized Reserve – Regulating Units
 - Synchronized Reserve – Non-regulating Units
 - Regulation Assignment will be subtracted from Synchronized Reserve total in calculation
 - Same MWs can not be counted as Regulation and Synchronized Reserve
- Intent is to simplify calculations to improve data quality
- Changes will be made to EMS and eDART IRC prior to Shortage Pricing Implementation




- Synchronized Reserve
 - Lesser of:
 - (Spin Ramp Rate * 10 minutes)
 - Synchronized Max limit – current output

If no Synchronized Reserve Maximum limit is specified in eMKT, the Economic High limit is used.

- Synchronized Reserve

EXAMPLE



Synchronized Reserve = lesser of

- $(5 \text{ MW/min} * 10 \text{ Min}) = 50 \text{ MW}$

- $150(\text{Synchronized Max}) - 95(\text{Current Output}) = 55 \text{ MW}$

Synchronized Reserve = 50 MW

Limited by Synchronized Ramp Rate


- Quick Start Reserve
 - Generation available within 10 minutes for Offline reserve unit
 - Synchronized Maximum Limit
 - » Limited by Ramp Rate * (10 – Time to Start)

Time to Start = Notification time + Startup Time

Only offline units that have a (Notification time + Startup Time) \leq 10 minutes are included in the calculation

- Quick Start Reserve

EXAMPLE



Notification +
Startup Time = 3
minutes

Quick Start Reserve =
• Synchronized Max = 50 MW
Quick Start Reserve = 50 MW

- Operating Reserve
 - Generation available within 30 minutes from Offline or Online reserve units
 - Operating Reserve = Offline + Online
 - Offline
 - Synchronized Maximum Limit
 - » Limited by Ramp Rate * (30 – Time to Start)


Time to Start = Notification time + Startup Time

Only offline units that have a (Notification time + Startup Time) \leq 30 minutes are included in the calculation

- Operating Reserve
 - Generation available within 30 minutes from Offline or Online reserve units
 - Operating Reserve = Offline + Online
 - Online
 - Lesser of
 - Spin Ramp rate * (30 minutes)
 - Synchronized Maximum Limit – Current MW level

- Operating Reserve – Offline Unit

EXAMPLE




Spin Ramp rate =
10 MW/min

Notification +
Startup Time = 15
minutes

Operating Reserve = 100 MW

- Operating Reserve Online Unit

EXAMPLE



Operating Reserve =

- $3 \text{ MW/min} * (30 \text{ Min}) = 90 \text{ MW}$
- Synchronized Max – Current MW = $100 - 20 = \mathbf{80 \text{ MW}}$

Operating Reserve = 80 MW

Limited by Synchronized Max

- **Secondary/Supplemental Reserve**
 - Generation available within 10-30 minutes
 - Secondary Reserve = Operating Reserve – Primary Reserve

Display View Overlay Tools

Help

Empower SPECTRUM

Reserve Monitor Overview

Zonal Report

PRINT

Unit Res

Gen IRC

RTO Over

Online Units Only **OFF**


Reserve Category	RTO	RFC	Mid Atlantic		South	West	NI	VACAR Reserves
			Eastern	Total				
Normal Reg. Res.	783	754	442	526	29	98	130	0
Primary	3994	2726	1253	1777	1268	832	117	
Total Spinning	2479	1980	587	1031	499	832	117	
Spin N Reg	2189	1720	539	972	469	651	97	
Spin Reg	290	260	48	59	30	181	20	
Quick Start	1515	746	666	746	769	0	0	
Secondary	11947	11228	3986	5553	719	3586	2089	
Operating	15941	13954	5239	7330	1987	4418	2206	
Beyond Secondary	18104	15793	3196	4923	2311	5720	5150	
Pump Trip	0	0	0	0	0	0	0	
Max Emergency	xxx	xxx	xxx	xxx	xxx	xxx	xxx	
Spinning Alarm		1300	0	896		0	0	
Primary Alarm		2000		1700	423	0	0	
GPM Spinning	1421	1162	329	543	259	369	250	
Spinning Delta	-1212	-1022	-304	-549	-190	-478	5	
GPM Primary	2936	1908	995	1289	1028	369	250	
Primary Delta	-1212	-1022	-304	-549	-190	-478	5	

- When reviewing historical data (from 8/8/07 and other days) and operating situations, it is evident that the data quality of the existing generator operating and market parameters needs to be improved
 - What was expected based on unit data did not match actual situation
 - Data not being updated consistently
 - Reliability and Economic implications

- Synchronized Reserve Ramp Rate
 - Can be higher than Energy Ramp Rate
 - May not be physically achievable by generating units
 - Leads to overstating of reserves
- Difference between Synchronized Reserve Max and Economic Max
 - Synch Max \geq Eco Max
 - Synch Max \leq Emerg Max
 - Units appear reluctant to exceed Economic Max during Synch Reserve events
 - Leads to overstating of reserves

- **Synchronized Reserve Ramp Rate (MW/Min)**
 - Used in calculation of Synchronized and Operating Reserve
 - Can be changed daily
- **Unit limits**
 - Specifically Synchronized Reserve Max Limit
 - Economic Max \leq Synch Reserve Max \leq Emergency Max
 - Can be changed hourly
- **Startup Time**
 - Used to determine eligibility for Quick Start and Operating Reserve
 - Can be changed daily
- **Notification Time**
 - Used to determine eligibility for Quick Start and Operating Reserve
 - Can be changed hourly (to accommodate staffing issues)

- Increased interaction/feedback from plant operators
 - Get the data from the plant to PJM!
 - Automated updating (Dominion)
 - Data needs to be based on physical unit characteristics
- Utilize eMKT Weather Data Curves for CT limits



- Better monitoring/situational awareness by Gen Operators
 - Can utilize eMKT Dispatch Lambda screen to see current unit data being utilized
 - Update hourly values as required in eMKT
 - Notify PJM Operations of known data problems
- Technology Updates
 - New IRC reporting format scheduled for development in eDART
 - Generation Performance Monitoring Tool
 - Rolled out in 2009
 - Some performance problems being worked on

- PJM also calculating on EMS Synchronized Reserve and Primary Reserve utilizing:
 - GPM-adjusted Ramp Rates
 - Economic Max Limits
- Provides for a more conservative reserve calculation for comparison with normal calculations

- The following events should NOT trigger Shortage Pricing by themselves
 - Loading of Synchronized or Quick Start Reserves (i.e. unit loss)
 - Implementation of Shared Reserves
 - Transaction Ramping out of PJM
- In most cases, these are transient events and not true Shortage situations
 - However, if coupled with peak load conditions, these type of events could initiate a reserve shortage