



Summary of FERC 792

Andrew Levitt

Aug 24 MRC session on DER

Ruling applies to pro-forma Small Generator Interconnection Procedures and Agreement (SGIP and SGIA):

1. Pre-application report request
2. Fast track for inverter-based: 2MW → 5MW
3. Fast track screen fallback
4. Allow written comments from customer
5. Include energy storage
6. Tweak time and cost requirements

PJM changed Tariff to comply with FERC directives with only minor variations.

- Changed definition of Small Generation Facility in the Small Generator Interconnection Agreement to include the underlined :

“Small Generating Facility – The Interconnection Customer's device for the production and/or storage for later injection of electricity identified in the Interconnection Request, but shall not include the Interconnection Customer's Interconnection Facilities.”