



# Review of 2021 RTEP Assumptions Update

Transmission Expansion Advisory  
Committee

February 9, 2021

- 2021 RTEP
  - TPL-001-4
- Modeling
  - MOD-032 (GOs and TOs)
    - <http://pjm.com/planning/rtep-development/powerflow-cases/mod-032.aspx>
    - Siemens PSS®MOD - Model On Demand (TOs)
    - PJM.com Planning Center Online Tool (Gen Model) – GOs

(No changes from January 2021 presentation)

- November 2020: Establish 2021 RTEP base case modeling assumptions  
November 2020 to February 2021: Build base cases and perform initial case review. During this period,
  - New modeling and other basic assumption changes will not be considered unless PJM determines they may have a significant impact on the RTEP baseline studies.
  - Corrections to the analytical files will be accepted.
- February to May 2021: Perform RTEP baseline studies. During this period,
  - No new modeling or other basic assumption changes will be made.
  - Corrections to the analytical files will only be accepted if they have a widespread impact or will likely impact one or more identified violations.

(No changes from January 2021 presentation)

- June/July 2021
  - Open competitive proposal window
  - Post modeling assumptions changes and corrections for and begin mid-year retool of 2021 RTEP baseline analysis
    - Accounts for major new modeling assumption changes and corrections not previously considered.
    - Basic assumptions such as planning criteria and ratings methodology that changed after February will not be considered until the 2022 RTEP.
- July/August 2021
  - Close competitive proposal window
  - Finalize mid-year retool
- August to October 2021: Evaluate proposals
- October to December 2021: Approve proposals

(No changes from January 2021 presentation)

- **Load Flow Modeling**

- Power flow models for outside world load, capacity, and topology will be based on the following 2020 Series MMWG power flow cases
  - 2025SUM MMWG outside world for 2021 Series 2026SUM RTEP, 2024SUM RTEP
  - 2025SLL MMWG outside world for 2021 Series 2026LL RTEP
  - 2025WIN MMWG outside world for 2021 Series 2026WIN RTEP, 2024WIN RTEP
  - 2022SUM MMWG outside world for 2021 Series 2022SUM RTEP
- PJM to work with neighbors to identify any updates to topology/corrections
- PJM topology for all cases sourced from Model On Demand
  - Include all PJM Board approved upgrades through the December 2020 PJM Board of Manager approvals as well as all anticipated February 2021 PJM Board approvals
  - Include all Supplemental Projects included in a Local Plan as of 11/13/2020.

(No changes from January 2021 presentation)

- **Firm Commitments**
  - Long term firm transmission service consistent with those coordinated between PJM and other Planning Coordinators during the 2020 Series MMWG development
- **Outage Rates**
  - Generation outage rates will be based on the most recent Reserve Requirement Study (RRS) performed by PJM
  - Generation outage rates for future PJM units will be estimated based on class average rates

(No changes from January 2021 presentation)



# Generator Deliverability: Generic EEFORds

- Generic EEFORd values developed for 2026 RTEP base case
- Capacity weighted by fuel type
  - Each unit within a given generator class is assigned the average EEFORd for that class

Gen Class	MW	Avg EEFORD
Fossil Steam	60,708	10.42%
Nuclear	30,973	1.33%
Combustion Turbine	26,293	6.92%
Combined Cycle	62,417	3.56%
Hydro	2,941	7.89%
Pumped Storage	5,609	2.72%
Diesel	922	10.97%
Wind	2,044	0.00%
Solar	4,510	0.00%

(Table values updated for February 2021 presentation)

- **Summer Peak Load**
  - Summer Peak Load will be modeled consistent with the 2021 PJM Load Forecast Report
  - The final load forecast released in December 2020
- **Winter Peak Load**
  - Winter Peak Load will be modeled consistent with the 2021 PJM Load Forecast Report
- **Light Load**
  - Modeled at 50% of the Peak Load forecast per M14B
  - The Light Load Reliability Criteria case will be modeled consistent with the procedure defined in M14B
- **Load Management, where applicable, will be modeled consistent with the 2021 Load Forecast Report**
  - Used in LDA under study in load deliverability analysis

(No changes from January 2021 presentation)



# 2021 RTEP Generation Assumptions

- All existing generation expected to be in service for the year being studied will be modeled.
- Future generation with a signed Interconnection Service Agreement, or that cleared in the 2021/22 BRA, will be modeled along with any associated network upgrades.
  - Generation with a signed ISA will contribute to and be allowed to back-off problems.
- Generation with an FSA will be modeled consistent with the procedures noted in Manual 14B, is not expected to be required to meet target generation levels through the planning horizon, and therefore will not be considered in the RTEP analysis.
- Additional generation information (i.e. machine lists) will be posted to the TEAC page.

(No changes from January 2021 presentation)

- Queue projects with an FSA or ISA but are not included in 2021 Series RTEP cases
  - Y3-092 (MTX)
    - 1000 MW Capacity Transmission Injection Rights
    - 500 MW Firm Transmission Withdrawal Rights and 500 MW Non-Firm Transmission Withdrawal Rights

(No changes from January 2021 presentation)

- Generation that has officially notified PJM of deactivation will be modeled offline in RTEP base cases for all study years after the intended deactivation date
- RTEP baseline upgrades associated with generation deactivations will be modeled
- Retired units Capacity Interconnection Rights are maintained in RTEP base cases for 1 year after deactivation at which point they will be removed unless claimed by an queue project

(No changes from January 2021 presentation)

- At a minimum, all PJM bulk electric system facilities, all tie lines to neighboring systems and all lower voltage facilities operated by PJM will be monitored.
- At a minimum, contingency analysis will include all bulk electric system facilities, all tie lines to neighboring systems and all lower voltage facilities operated by PJM.
- Thermal and voltage limits will be consistent with those used in operations and those specified in the Form 715 planning criteria. In all cases, the more conservative value will be used.

(No changes from January 2021 presentation)

- **PJM/NYISO Interface**
  - B & C cables will be modeled out of service consistent with NYISO modeling
- **Linden VFT**
  - Modeled at 330 MW
- **HTP**
  - Modeled at 0 MW

(No changes from January 2021 presentation)

- As part of the 24-month RTEP cycle, a year 7 (2028) base case will be developed and evaluated as needed as part of the 2021 RTEP
- The year 7 case will be based on the 2026 Summer case that will be developed as part of this year's 2021 RTEP
- Purpose: To identify and develop longer lead time transmission upgrades

(No changes from January 2021 presentation)

- Similar to the 2020 RTEP and per the PJM Operating Agreement, a proposal window will be conducted for all reliability needs that are not Immediate Need reliability upgrades or are otherwise ineligible to go through the window process.
- FERC 1000 implementation will be similar to the 2020 RTEP.
  - Advance notice and posting of potential violations
  - Advance notice of window openings
  - Window administration

(No changes from January 2021 presentation)



# Locational Deliverability Areas (LDAs)

- Includes the existing 27 LDAs
- Total of 27 LDAs
  - All 27 to be evaluated for the as part of the 2020 RTEP

LDA	Description
<b>EMAAC</b>	Global area - PJM 500, JCPL, PECO, PSEG, AE, DPL, RECO
<b>SWMAAC</b>	Global area - BGE and PEPSCO
<b>MAAC</b>	Global area - PJM 500, Penelec, Meted, JCPL, PPL, PECO, PSEG, BGE, Pepco, AE, DPL, UGI, RECO
<b>PPL</b>	PPL & UGI
<b>PJM WEST</b>	APS, AEP, Dayton, DUQ, Comed, ATSI, DEO&K, EKPC, Cleveland, OVEC
<b>WMAAC</b>	PJM 500, Penelec, Meted, PPL, UGI
<b>PENELEC</b>	Pennsylvania Electric
<b>METED</b>	Metropolitan Edison
<b>JCPL</b>	Jersey Central Power and Light
<b>PECO</b>	PECO
<b>PSEG</b>	Public Service Electric and Gas
<b>BGE</b>	Baltimore Gas and Electric
<b>PEPCO</b>	Potomac Electric Power Company
<b>AE</b>	Atlantic City Electric
<b>DPL</b>	Delmarva Power and Light
<b>DPLSOUTH</b>	Southern Portion of DPL
<b>PSNORTH</b>	Northern Portion of PSEG
<b>VAP</b>	Dominion Virginia Power
<b>APS</b>	Allegheny Power
<b>AEP</b>	American Electric Power
<b>DAYTON</b>	Dayton Power and Light
<b>DLCO</b>	Duquesne Light Company
<b>Comed</b>	Commonwealth Edison
<b>ATSI</b>	American Transmission Systems, Incorporated
<b>DEO&amp;K</b>	Duke Energy Ohio and Kentucky
<b>EKPC</b>	Eastern Kentucky Power Cooperative
<b>Cleveland</b>	Cleveland Area

(No changes from January 2021 presentation)

- Request stakeholder suggestions for and input to 2021 alternative sensitivity studies and scenario analysis
- PJM will monitor the progress of the scenario studies being performed in collaboration with ISAC to determine the merit of considering any scenarios in approving projects for future inclusion in the RTEP.



V1 – 2/3/2020 – Original Slides Posted