

2022-2023

Stage 1A ARR 10 Year Analysis Update

Xu Xu, Lead Engineer

Transmission Expansion Advisory Committee
Tuesday, September 6, 2022

- Purpose:
 - Test the transmission system's ability to support the simultaneous feasibility of all Stage 1A ARR for base load plus the projected ten-year growth of base load
- Results:
 - 2022/2023 Stage 1A 10-Year ARR analysis identified one violation on internal facility
 - Upgrade anticipated as part of coordination with current RTEP development



Results of 2022/23 Stage 1A ARR 10-year Analysis

Facility Name	Facility Type	First Year of Violation	Upgrade expected to fix infeasibility	Expected in-service date
TMI 500 KV 1 BANK	XF	Y		TBD

Facilitator:
Sue Glatz,
Suzanne.Glatz@pjm.com

Secretary:
Mike Zhang,
Michael.Zhang@pjm.com

SME/Presenter:
Xu Xu,
Xu.Xu@pjm.com

2022/2023 Stage1A ARR 10year analysis



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com

Version No.	Date	Description
1	9/1/2022	<ul style="list-style-type: none">Original slides posted



**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**

Be alert to
malicious
phishing emails.



Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com