

ELCC Class Ratings for 2023/2024 3IA, 2025/2026 BRA and 2026/2027 BRA

| ELCC Class | 2023/2024 3IA | 2025/2026 BRA | 2026/2027 BRA |
|---|---------------|---------------|---------------|
| Onshore Wind | 15% | 15% | 13% |
| Offshore Wind | 42% | 40% | 31% |
| Solar Fixed Panel | 50% | 37% | 33% |
| Solar Tracking Panel | 61% | 51% | 45% |
| 4-hr Storage | 94% | 77% | 77% |
| 6-hr Storage | 100% | 96% | 94% |
| 8-hr Storage | 100% | 100% | 100% |
| 10-hr Storage | 100% | 100% | 100% |
| Solar Hybrid Open Loop - Storage Component | 93% | 74% | 83% |
| Solar Hybrid Closed Loop - Storage Component | 93% | 74% | 83% |
| Hydro Intermittent | 37% | 37% | 37% |
| Landfill Gas Intermittent | 63% | 63% | 64% |
| Hydro with Non-Pumped Storage* | 98% | 94% | 93% |

^{*} PJM performs an ELCC analysis for each individual unit in this class. The value shown in the table is a representative value provided for informational purposes