Pierce Brook Substation, Install 2nd 345 kV Reactor

General Information

Proposing entity name Company name appears in this field

Company proposal ID Company name appears in this field

PJM Proposal ID 855

Project title Pierce Brook Substation, Install 2nd 345 kV Reactor

Project description Install a second 125 MVAR 345 kV shunt reactor and associated equipment at Pierce Brook

05/2025

No

Substation. Install a 345 kV breaker on the high side of the #1 345/230 kV transformer.

Project in-service date

Tie-line impact

Interregional project
No

Is the proposer offering a binding cap on capital costs?

Reactor provides Transmission Operations with voltage control of the 345 kV system. Under
Additional benefits maintenance or unplanned outage conditions the second reactor allows Transmission Operations to continue controlling the 345 kV voltage.

Project Components

1. Install a second 125 MVAR 345 kV reactor at Pierce Brook

Substation Upgrade Component

Install a second 125 MVAR 345 kV reactor at Pierce Brook Component title

Pierce Brook Substation Substation name

Substation zone Penelec

2020-W1-855

Substation upgrade scope

Transformer Information

Transformer

Voltage (kV)

New equipment description

Substation assumptions

Real-estate description

Construction responsibility

Additional comments

Component Cost Details - In Current Year \$

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Install a second 125 MVAR 345 kV shunt reactor and associated facilities. Install a 345 kV breaker on the high side of the #1 345/230 kV transformer.

Name	Capacity (MVA)	
N/A	N/A	
High Side	Low Side	Tertiary
N/A	N/A	N/A

The new 345 kV shunt reactor will be rated for 125 MVAR absorption. Transformer high side circuit breaker and all associated equipment will be sized such that the loadability of all lines and transformers will be unchanged.

- Expanding the substation fence to fit the reactor. Moving the existing #1 345/230 kV transformer for clearance to install the high side breaker. FE will acquire additional land from the adjacent property owner. Cost for major equipment is based on a similar project in 2016 at this site.
- Single property owner for required expansion of ~1.8 acres.

Company name appears in the Construction Responsibility

N/A

This information is considered confidential and proprietary

2020-W1-855 2

Contingency This information is considered confidential and proprietary

Total component cost \$8,077,103.87

Component cost (in-service year) \$8,937,224.67

Congestion Drivers

None

Existing Flowgates

FG#	From Bus No.	From Bus Name	To Bus No.	To Bus Name	СКТ	Voltage	TO Zone	Analysis type
N2-WVM15	200942	26PIERCEBRK	200942	26PIERCEBRK	0	345	226	N-1-1 Voltage Mag(Winter
N2-WVM16	200942	26PIERCEBRK	200942	26PIERCEBRK	0	345	226	N-1-1 Voltage Mag(Winter
N2-WVM17	200942	26PIERCEBRK	200942	26PIERCEBRK	0	345	226	N-1-1 Voltage Mag(Winter
N2-WVM18	200942	26PIERCEBRK	200942	26PIERCEBRK	0	345	226	N-1-1 Voltage Mag(Winter
N2-WVM19	200942	26PIERCEBRK	200942	26PIERCEBRK	0	345	226	N-1-1 Voltage Mag(Winter
N2-SVM52	200942	26PIERCEBRK	200942	26PIERCEBRK	0	345	226	N-1-1 Voltage (Summer)
N2-SVM53	200942	26PIERCEBRK	200942	26PIERCEBRK	0	345	226	N-1-1 Voltage (Summer)
N2-SVM54	200942	26PIERCEBRK	200942	26PIERCEBRK	0	345	226	N-1-1 Voltage (Summer)
N2-SVM55	200942	26PIERCEBRK	200942	26PIERCEBRK	0	345	226	N-1-1 Voltage (Summer)

New Flowgates

None

Financial Information

Capital spend start date 06/2023

Construction start date 08/2024

Project Duration (In Months) 23

2020-W1-855 3

Additional comments

None

2020-W1-855