## Bremo TX#9 Load Relief~Alternative 1~Bear Garden to Fork Union Connection

## **General Information**

Additional benefits

Proposing entity name The redacted information is proprietary to the Company; therefore, it is privileged and confidential. Does the entity who is submitting this proposal intend to be the The redacted information is proprietary to the Company; therefore, it is privileged and confidential. Designated Entity for this proposed project? Company proposal ID The redacted information is proprietary to the Company; therefore, it is privileged and confidential. PJM Proposal ID 473 Bremo TX#9 Load Relief~Alternative 1~Bear Garden to Fork Union Connection Project title Re-route one (1) circuit from the Bremo substation to the Fork Union substation, approximately 1.6 Project description miles. All transmission line will be installed within the existing ROW extents via the use of one (1) set of double circuit structures. Line 2193 (230kV) will be rebuilt with the existing line 2111 (230kV). This proposal provides a direct connect between Bear Garden substation and Fork Union substation by wrecking and rebuilding line #2193 as a double circuit using a conductor with summer rating of 1573MVA and connecting it to line #2111. Fiber optic communication will be considered for this line. At Fork Union, line leads for line #2193 will be upgraded to 4000A. Also, line #2111 will be terminated into a third row of breaker and a half string with two 4000A breakers and associated switches. This will lead to line #2111 Bear Garden - Fork Union and Line #2193 Bremo - Fork Union. No upgrades at Bear Garden is required. However, controller and relay setting will be updated. **Email** The redacted information is proprietary to the Company; therefore, it is privileged and confidential. 06/2027 Project in-service date Tie-line impact No Interregional project No Is the proposer offering a binding cap on capital costs? No

2022-W2-473

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

# **Project Components**

- 1. 230kV Line #2193 (Bremo to Fork Union) wreck and rebuild
- 2. Extension of 230kV Line #2111 Bear Garden to Fork Union
- 3. Bear Garden Substation 230kV Termination relay update
- 4. Bremo Substation 230kV Line Removal
- 5. Fork Union Substation 230kV line Termination

## **Transmission Line Upgrade Component**

Component title 230kV Line #2193 (Bremo to Fork Union) wreck and rebuild

Project description

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Impacted transmission line Line #2193

Point A Bremo

Point B Fork Union

Point C

Terrain description

The project area is in the central Virginia Piedmont region with elevations ranging from approximately 200 to 360 feet. The terrain is predominately vegetated existing right-of-way consisting of moderate slopes. The line will cross no roads, a railroad track, several small streams, and one Section 10 Navigable waterway (James River).

Existing Line Physical Characteristics

Operating voltage 230

Conductor size and type 2-636 ACSR (24/7) 150°C MOT [0.11 miles]; 2-721 ACAR (18/19) 90°C MOT [1.63 miles]

Hardware plan description Existing segment of the line will remain as is. For the extension segment, new hardware will be used. The existing hardware were installed in 1980's.

Tower line characteristics

Most of the existing structures are built in 1980's and are suitable for single circuits. New Structures are being installed to accommodate with extension of lines #2111.

#### **Proposed Line Characteristics**

Voltage (kV)

Summer (MVA)

Winter (MVA)

Conductor size and type

Shield wire size and type

Rebuild line length

Rebuild portion description

Right of way

Construction responsibility

Benefits/Comments

#### Component Cost Details - In Current Year \$

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

**Designed** Operating

230.000000 230.000000

Normal ratings Emergency ratings

1573.000000 1573.000000

1648.000000 1648.000000

2-768 ACSS/TW-HS (20/7) 250°C MOT [1.5 miles], 2-721 ACAR (18/19) 90°C MOT [.06 miles]

DNO-11410 OPGW shield wire

1.6

See Scope of Work in attachments for designation of removed, modified and installed structures.

No new or additional right of way is required to complete this project.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

2022-W2-473 3

Contingency The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Total component cost \$3,263,786.14

Component cost (in-service year) \$3,495,514.96

## **Transmission Line Upgrade Component**

Component title Extension of 230kV Line #2111 Bear Garden to Fork Union

Project description The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Impacted transmission line Line #2111

Point A Bear Garden

Point B Fork Union

Point C Bremo

Terrain description

The project area is in the central Virginia Piedmont region with elevations ranging from approximately 200 to 360 feet. The terrain is predominately vegetated existing right-of-way consisting of moderate slopes. The line will cross no roads, a railroad track, several small streams,

and one Section 10 Navigable waterway (James River).

#### **Existing Line Physical Characteristics**

Operating voltage 230

Conductor size and type 2-636 ACSR (24/7) 150°C MOT [1.34miles]

Hardware plan description Existing segment of the line remains as is. For the extension segment, new hardware will be used.

1.6 miles of DNO-11410 OPGW will be installed. The existing structures were installed in 1980's.

Tower line characteristics New structures will be used for the extension.

**Proposed Line Characteristics** 

Voltage (kV) 230.000000 230.000000

**Designed** 

2022-W2-473

**Operating** 

Summer (MVA)
Winter (MVA)
Conductor size and type
Shield wire size and type
Rebuild line length
Rebuild portion description
Right of way
Construction responsibility
Benefits/Comments
Component Cost Details - In Current Year \$
Engineering & design
Permitting / routing / siting
ROW / land acquisition
Materials & equipment
Construction & commissioning
Construction management
Overheads & miscellaneous costs
Contingency
Total component cost
Component cost (in-service year)

Normal ratings	Emergency ratings						
1573.000000	1573.000000						
1648.000000	1648.000000						
2-768 ACSS/TW-HS (20/7) 250°C MOT							
DNO-11410 OPGW shield wire							
1.6							
See Scope of Work in attachments for designation of removed, modified and installed structures.							
No new or additional right of way is required to complete this project.							
The redacted information is proprietary to the Co	The redacted information is proprietary to the Company; therefore, it is privileged and confidential.						
The redacted information is proprietary to the Co	he redacted information is proprietary to the Company; therefore, it is privileged and confidential.						
The redacted information is proprietary to the Co	ompany; therefore, it is privileged and confidential.						
The redacted information is proprietary to the Co	ompany; therefore, it is privileged and confidential.						
The redacted information is proprietary to the Co	ompany; therefore, it is privileged and confidential.						
The redacted information is proprietary to the Co	ompany; therefore, it is privileged and confidential.						
The redacted information is proprietary to the Co	ompany; therefore, it is privileged and confidential.						
The redacted information is proprietary to the Co	ompany; therefore, it is privileged and confidential.						
The redacted information is proprietary to the Co	ompany; therefore, it is privileged and confidential.						
The redacted information is proprietary to the Co	ompany; therefore, it is privileged and confidential.						
\$4,696,667.87							

2022-W2-473 5

\$5,030,131.28

## **Substation Upgrade Component**

Component title

Project description

Substation name

Substation zone

Substation upgrade scope

#### **Transformer Information**

None

New equipment description

Substation assumptions

Real-estate description

Construction responsibility

Benefits/Comments

### **Component Cost Details - In Current Year \$**

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Bear Garden Substation 230kV Termination relay update

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Bear Garden

363

N/A

No new substation equipment will be installed as part of this proposal.

1. Relay Settings and protection & control design for the new line termination will be revised as part of the SPE scope of work. 2. The scope of work depicted on the drawings assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary.

The substation will not be expanded for this project.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Contingency

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Total component cost

\$162,599.00

Component cost (in-service year)

\$174,143.53

## **Substation Upgrade Component**

Component title Bremo Substation 230kV Line Removal

Project description

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Bremo

Substation name
Substation zone

363

Substation upgrade scope

Retire substation material: 1. Retire one (1) 230kV, 3000A, Breaker 211122, associated foundations, grounding, and terminal connections. 2. Retire one (1), 230 kV, 3000A 3-Phase Center Break Switch 211125 and terminal connections. 3. Retire three (3) 230kV, CCVTs 2111P1, 2111P2, 2111P3, associated foundations, steel, and terminal connections. 4. Retire three (3), 180 kV, 144 kV MCOV, Station Class Surge Arresters associated foundations, steel, and terminal connections. Retire relay material: 1. Two (2), Panel Retirement (Panel 37 and 46)

#### **Transformer Information**

None

New equipment description

Substation assumptions

Real-estate description

Construction responsibility

Benefits/Comments

**Component Cost Details - In Current Year \$** 

Engineering & design

No new substation equipment will be installed as part of this proposal.

1. Relay Settings and protection & control design for the new line termination will be revised as part of the SPE scope of work. 2. The scope of work depicted on the drawings assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary.

The substation will not be expanded for this project.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

2022-W2-473 7

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Contingency

Total component cost

Component cost (in-service year)

## **Substation Upgrade Component**

Component title

Project description

Substation name

Substation zone

Substation upgrade scope

#### **Transformer Information**

None

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

\$295,125.00

\$316,078.88

Fork Union Substation 230kV line Termination

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

Fork Union

363

Purchase and install: Breakers, connectors, leads, insulators, and grounding materials as per engineering standards.

New equipment description

Substation assumptions

Real-estate description

Construction responsibility

Benefits/Comments

#### **Component Cost Details - In Current Year \$**

Engineering & design

Permitting / routing / siting

ROW / land acquisition

Materials & equipment

Construction & commissioning

Construction management

Overheads & miscellaneous costs

Contingency

Total component cost

Purchase and install substation material: 1. Two (2), 230kV, 4000A, 63kAIC, SF6 Circuit Breakers 2. Two (2), 230 kV, 4000A 3-Phase Center Break Switches. 3. Four (4), 230kV, Relay Accuracy CCVTs 4. Three (3), 180 kV, 144 kV MCOV, Station Class Surge Arresters. 5. Foundations and steel structures as required. 6. Conductor, connectors, conduit, control cable, and grounding material per engineering standards. Purchase and install relay material: 1. Two (2), 4510 - SEL-2411 Equipment Annunciator 2. One (1), 1110 – 28" Dual SEL-587Z Transmission Bus Panel 3. One (1), 4200 – Bus Differential C.T. Makeup Box 4. Two (2), 1510 – 28" Dual SEL-351 Transmission Breaker w/ Reclosing Panel 5. One (1), 4506 – 3 Phase CCVT Potential Makeup Box 6. One (1), 4507 - Single Phase CCVT Potential Makeup Box 7. One (1), 1340 – 28" Dual SEL-411L CD/Fiber Line Panel 8. Two (2), 4526\_A – Circuit Breaker Fiber Optic Makeup Box 9. One (1), Panel Retirement (Panel 5)

1. Relay Settings and protection & control design for the new line termination will be revised as part of the SPE scope of work. 2. The scope of work depicted on the drawings assumes that there is no overlap with other designs and construction activities, except if mentioned in this Project Summary. 3. 4-hole pad connections must be replaced with 6-hole connections to maintain 4000A ratings.

The substation will not be expanded for this project.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

\$1,675,814.30

# **Congestion Drivers**

None

# **Existing Flowgates**

FG#	Fr Bus No.	From Bus Name	To Bus No.	To Bus Name	СКТ	Voltage	TO Zone	Analysis type	Status
2022W2-GD-LL1	314747	6BREMO	314744	3BREMO	1	230/115	345/345	Light Load Generation Delivera	albirlitlyuded
2022W2-N1-LLT1	314747	6BREMO	314744	3BREMO	1	230/115	345/345	Light Load Baseline	Included

# **New Flowgates**

The redacted information is proprietary to the Company; therefore, it is privileged and confidential.

## **Financial Information**

Capital spend start date 06/2025

Construction start date 06/2026

Project Duration (In Months) 24

## **Additional Comments**

None