

Vistra and Constellation

Expanded Eligibility for Resources Participating in PJM's RBA

CIFP Stages 2 & 3 Meetings

May 4-5, 2026

Allow three additional resource categories to be eligible to participate in the RBA

1) Replacement resources

- A new resource includes one that commits to utilizing PJM's replacement process to acquire transferred CIRs from a deactivating resource and thus would be eligible for the RBA. Such resource would be required to follow the other requirements of the RBA, in particular, the COD date.

2) New Product: Voluntary large load limited demand response

- Allow large load to clear as limited demand response. Discounted Effective Load Carrying Capability (ELCC) to reflect the reduced availability. Two, new limited products would be defined as:
 - 24 hours/year with no single interruption greater than 6 hours
 - 100 hours/year with no single interruption greater than 10 hours

3) New Product: Back-up generator operations

- Provide relief during system emergencies using back-up generators. Agree to operate within criteria acceptable to the owners (i.e., consistent with their commitment to the environment, noise reduction, etc.). Establish new PJM emergency procedure step, 9A, for deployment immediately prior to manual load dump. Discounted ELCC to reflect the reduced availability.