

**From:** Pete Fuller

**Sent:** Monday, November 25, 2024 2:40 PM

**To:** <mailto:StakeholderAffairsTeam@pjm.com>

**Subject:** surplus interconnection service tariff proposal

In Sec VIII.E.414.B.3, the proposed language says that a SIS request will be terminated if there may be network upgrades or voltage/stability issues. All the earlier references to the standard appear to require an affirmative determination that such upgrades or impacts would be necessary or occur. Suggest removing the conditional nature of the standard in B.3.

Thanks. Pete.



**AUTUMN LANE  
ENERGY CONSULTING LLC**

Pete Fuller  
508.944.5075  
[pete@autumnlaneenergy.com](mailto:pete@autumnlaneenergy.com)