





2026/2027 ARR/FTR Update

Market Implementation Committee

February 4th, 2026

- 2026/2027 ARR allocation and FTR Auction
 - ARR Setup dates
 - Timeline of annual allocation and auction
 - Annual preparations
- 2026/2027 IARRs for RTEP upgrades





- Zonal Network Service Peak Load (NSPL)
- ARR Stage1 Resources
- Point-to-Point ARR nomination form
- Model Information
 - Transmission outages
 - Key system upgrades
 - Market-to-Market Flowgates Entitlements
 - Contingencies

- Overview
 - PJM Operating Agreement requires annual IARR analysis for eligible RTEP upgrades scheduled to be in-service for 2026/27 planning year
- Analysis Results
 - No IARRs could be awarded for eligible RTEP upgrades
 - See Appendix for Analysis Details
- Previously approved RTEP IARRs will populate at FTR Center

Chair:
Jason Shoemaker,
Jason.shoemaker@pjm.com

Secretary:
Stefan Starkov,
Stefan.Starkov@pjm.com

SME/Presenter:
Xu Xu, Xu.Xu@pjm.com or
FTRGroup@pjm.com

2026/2027 ARR/FTR Update



Member Hotline
(610) 666-8980
(866) 400-8980
custsvc@pjm.com



Appendix

Project	Type	Upgrade Description	In-Service Date	Pre-Upgrade ARR Capability	Pre-Upgrade Limit	Post-Upgrade ARR Capability	Post-Upgrade Limit	IARR MW
b3775	Merchant	Upgrade the limiting element at Dumont substation to increase the rating of the Stillwell-Dumont 345 kV line and Upgrade the existing terminal equipment (substation conductor) at St. John and Green Acres on the existing 345 kV lines	12/1/2026	0	LALLEND0345 KV LAL-MON I/o L345.AllenJunction-Morocco (ITC) Tie	0	LALLEND0345 KV LAL-MON I/o L345.AllenJunction-Morocco (ITC) Tie	0
b3850	Backbone	Rebuild approximately 13.51 miles of 500 kV line from Yadkin substation to Fentress substation.	12/31/2026	0	AP SOUTH for I/o BLA-BED	0	AP SOUTH for I/o BLA-BED	0
b3852	Merchant	Replace 765 kV breaker D at Maliszewski station.	6/1/2027	0	4 QUAD C345 KV TR1 18 / 4 QUAD C345 KV TR2 18	0	4 QUAD C345 KV TR1 18 / 4 QUAD C345 KV TR2 18	0
b3800.121	Backbone	Kammer to 502 Junction 500 kV line: Conduct LIDAR Sag Study to assess SE rating and needed upgrades.	6/1/2027	0	DOUBS 500 KV DOU-GOO I/o L500.BurchesHill-PossumPoint.560	0	DOUBS 500 KV DOU-GOO I/o L500.BurchesHill-PossumPoint.560	0
b3800	Backbone	Construct 35.8 miles of 500 kV overhead AC line between the Conastone vicinity and the Doubs substations (BGE zone portion) and other related upgrades	6/1/2027	0	CONASTON500 KV CNS-PEA I/o L500.PeachBottom-TMI.5007	0	CONASTON500 KV CNS-PEA I/o L500.PeachBottom-TMI.5007	0



**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



**BE ALERT TO
MALICIOUS PHISHING
EMAILS**



**Report suspicious email activity to PJM.
Call (610) 666-2244 or email it_ops_ctr_shift@pjm.com**