

M13 Section 3 Wild Fire Procedures

Kevin Hatch
Sr. Manager, Dispatch

Markets and Reliability Committee
January 23, 2025

- Frequent events across PJM system
- Limited existing PJM manual language
- Incorporated feedback from last SOS meeting

- **PJM Actions**

- Consult with staff meteorologists to evaluate extent of wild fire risk and discuss with impacted transmission and generation owners.
- Run real time and future studies for impacted transmission facilities that may have to come out of service due to active fires
- Coordinate with Transmission Owners to evaluate restoration of outaged transmission lines and cancellation of future outages.
- Evaluate if conservative operations needs to be issued under section 3.2 of M13
- Conduct System Operations Subcommittee calls, as needed
- Ensure that neighboring Reliability Coordinators are aware of fires, as needed

- **Transmission Owner Actions**

- Monitor wild fire red flag warnings and high risk wild fire risk conditions that may impact the BES. Notify PJM of red flag wild fire warnings as deemed necessary.
- Notify PJM in advance or as soon as possible of any circuits that will be de energized due to fires or to prevent wild fire risk
- Evaluate existing and future transmission outages and communicate to PJM the need to recall or reschedule outages
- Evaluate and communicate to PJM the need to turn off reclosing on any MP1 facilities **and other facilities as determined by the TO**
- Review and evaluate ratings on facilities that are impacted by fires and communicate to PJM if there is the need to derate facilities

Presenter:
Kevin Hatch
Kevin.Hatch@pjm.com



Member Hotline

(610) 666 – 8980


(866) 400 – 8980

custsvc@pjm.com

**PROTECT THE
POWER GRID**
**THINK BEFORE
YOU CLICK!**



**BE ALERT TO
MALICIOUS PHISHING
EMAILS**



Report suspicious email activity to PJM.
Call (610) 666-2244 or email it_ops_ctr_shift@pjm.com