



Executive Summary Manual Changes

Effective Date	June 24, 2026
Impacted Manual #(s)/Manual Title(s): Manual 13: Emergency Operations	
Conforming Order(s): N/A	
Associated Issue Tracking Title:	N/A
Committee Approval Path - What committee(s) have already seen these changes? SOS, RSCS, OC, MRC	
MRC 1st read date:	6/24/26
MRC voting date:	6/24/26
Impacted Manual sections: 2.3, 2.3.2, 3.3.2, 3.4, 5, 5.1, 5.2, Attachment D, Attachment E, Attachment F, Attachment O	
Reason for change: Periodic Review	
Summary of the changes: Revision 98 (06/24/2026): <ul style="list-style-type: none">• Periodic Review updated to address:• Updated manual ownership from Kevin Hatch to Paul Dajewski• Cover-to-cover changes: Corrected punctuation, spelling, grammar, and adjusted formatting for ease of use• Updated Advisory description and added Capacity Advisory to Section 2.3 and updated Exhibit 1 graphic• Added RCIS notification to Pre-Emergency Load Management Reduction Action	

- Updated verbiage for Advanced Schedule Resources under Section 3.3.2 Cold Weather Alert and 3.4 Hot Weather Alert
- Removed specific time of notice for Heavy Load Voltage Schedule Warning Section 5.1.2
- Added "Transmission Security" to a majority of Section 5.2 Transmission Security Emergency Procedures
- Added note stating Section 5.2 Transmission Security Emergency Procedures do not trigger PAIs or EEAs and removed references to those triggers
- Split Maximum Generation Emergency / Load Management Alert in Section 5.2 into Transmission Security - Local Maximum Generation Emergency Alert and Transmission Security - Load Management Alert
- Removed actions specific to capacity issues from all Section 5.2 Transmission Security Emergency Procedures
- Removed Step 3 Primary Reserve Warning from Section 5.2
- Updated Section 5.2 Maximum Generation Emergency Action to Transmission Security - Local Maximum Generation Emergency Action
- Updated Attachment D information
- Updated Attachment E and F tables
- Added Attachment O: Emergency Use of Back-up Generators