M21B 10.3

8. In addition to #6 above, Net Capability of multiple generating units that are connected behind a single revenue meter and have CIRs issued based on that single revenue meter, must be determined by the simultaneous testing of all generating units behind a single revenue meter for the aforementioned durations. [APPEND] Multiple units behind one settlement meter can test separately in the circumstance where one unit is part of a separately operated power block that is behind a separate settlement meter.