

System Operations Report


Marcus Smith, Lead Engineer – Markets Coordination

David Kimmel, Sr. Engineer II – Performance Compliance

Operating Committee


January 9, 2025

Average Load Forecast Error





Daily Peak Forecast Error (December)







Days Exceeding 3% Forecast Error at Peak Hour

Over-forecasting

Dec. 12 Dec. 23 Dec. 25 **Dec. 30 Dec. 31** Loads came in higher as there was more than Colder than Holiday Temperatures in Temperatures usual uncertainty due to a large model spread, influence led to forecasted East were 3-6°F 2-6°F warmer recent holiday impacts & historical holiday temperatures lower loads warmer than than forecast: analysis but loads were coming off an holiday impact forecast in lower due to unseasonably afternoon greater than warm weekend holiday impacts anticipated






Under-forecasting

www.pjm.com | Public









Operational Summary (December)

- The following Emergency Procedures occurred:
 - -4 Shared Reserve events
 - -1 Spin Event
 - 1 High System Voltage Action
 - -2 Cold Weather Alerts
 - 16 Post Contingency Local Load Relief Warnings (PCLLRWs)




Shortage Case Approvals

- 1 Shortage Case Approved
- The approved Shortage Cases occurred on:
 - 12/06/2024:
 - -1 shortage case approved for the 17:40 interval
 - Factors: load and Interchange increase




RTO Generation Outage Rate - Monthly



The 13-month average forced outage rate is 4.20% or 8,290 MW. The 13-month average total outage rate is 14.82% or 29,201 MW.




2023-2024 Planned Emergency, Unplanned, and Total Outages by Ticket (Transmission Only)



Apjn

PCLLRW Count Vs. Peak Load – Daily Values For 3 Months



Jpjm[®]

Spin Response

Event	1		
Date	12/11/24		
Start Time	08:21:22		
End Time	08:27:22		
Duration	00:06:00		
Region	RTO		
Resource Type	Gen	DR	Total
Assigned (MW)	1872	643	2515
Estimated Expected Response of Assigned Resources (MW)	1123	386	1509
Actual Response of Assigned Resources (MW)	821	431	1253
Output Increase of Resources without Assignment (MW)	865	0	865
Percent Response To Estimated Expected Response (%)	73%	112%	83%
Penalty (MW)	0	0	0



"pjm

Load Forecast Report **Presenter/SME:** Marcus Smith, Marcus.Smith@pjm.com System Operations Report **Presenter:** David Kimmel, David.Kimmel@pjm.com SME: Ross Kelly, Ross.Kelly@pjm.com

Member Hotline (610) 666 – 8980 (866) 400 – 8980 custsvc@pjm.com




Appendix



Goal Measurement: Balancing Authority ACE Limit (BAAL)

- The purpose of the new BAAL standard is to maintain interconnection frequency within a predefined frequency profile under all conditions (normal and abnormal), to prevent frequency-related instability, unplanned tripping of load or generation, or uncontrolled separation or cascading outages that adversely impact the reliability of the interconnection. NERC requires each balancing authority demonstrate real-time monitoring of ACE and interconnection frequency against associated limits and shall balance its resources and demands in real time so that its Reporting ACE does not exceed the BAAL (BAAL_{LOW} or BAAL_{HIGH}) for a continuous time period greater than 30 minutes for each event.
- PJM directly measures the total number of BAAL excursions in minutes compared to the total number of minutes within a month. PJM has set a target value for this performance goal at 99% on a daily and monthly basis. In addition, current NERC rules limit the recovery period to no more than 30 minutes for a single event.

RTO Generation Outage Rate - Daily



The 13-month average forced outage rate is 4.20% or 8,290 MW. The 13-month average total outage rate is 14.82% or 29,201 MW.

Apjm

PCLLRW Count Vs. Peak Load – Daily Values For 13 Months

