

System Operations Report

Marcus Smith, Lead Engineer –
Markets Coordination


David Kimmel, Sr. Engineer II –
Performance Compliance

Operating Committee


August 7th, 2025

Average Load Forecast Error

July 2025
Hourly Error: **1.70%** Peak Error: **1.78%**



Daily Peak Forecast Error (July)



Days Exceeding 3% Forecast Error at Peak Hour

Over-forecasting

July 19


Scattered showers and thunderstorms across the footprint led to lower than forecast temperatures, leading to less load pull and over-forecasting.


July 24

Cooler than forecast temperatures and storms in the western footprint led to a 12°F drop in temperature, impacting peak loads.

July 26

Scattered showers and thunderstorms led to cooler temperatures all around, leading to less load pull and over-forecasting.






PJM's BAAL performance has exceeded the goal of 99% for each month in 2024 and 2025.

- The following Emergency Procedures occurred:
 - 4 Spin Event
 - 2 Shared Reserve event
 - 7 NERC EEA Level 1
 - 7 Maximum Generation Emergency Alerts
 - 5 Pre-Emergency Load Management Reduction Actions
 - 10 Hot Weather Alerts
 - 39 Post Contingency Local Load Relief Warnings


- 7 Shortage Cases Approved
- The approved Shortage Cases occurred on:
 - 07/28/2025:
 - 1 shortage cases approved for 12:15 interval
 - Factors: Mainly due to generation loss
 - 6 shortage cases approved for intervals between 18:59 and 19:25
 - Factors: Due to solar dropping out rapidly, while load did not drop as quickly as anticipated

RTO Generation Outage Rate - Monthly




The 13-month average forced outage rate is 5.09% or 10,097 MW.
 The 13-month average total outage rate is 15.39% or 30,491 MW.

2024-2025 Planned Emergency, Unplanned, and Total Outages by Ticket (Transmission Only)



Note: "Unplanned Outages" include tripped facilities. One tripping event may involve multiple facilities.

PCLLRW Count Vs. Peak Load – Daily Values For 3 Months



Event	1			2			3			4		
Date	07/01/25			07/22/25			07/30/25			07/31/25		
Start Time	10:18:26			15:11:28			13:31:31			01:33:40		
End Time	10:29:04			15:22:00			13:37:28			01:39:56		
Duration	00:10:38			00:10:32			00:05:57			00:06:16		
Region	RTO			RTO			RTO			RTO		
Resource Type	Gen	DR	Total	Gen	DR	Total	Gen	DR	Total	Gen	DR	Total
Assigned (MW)	2398	544	2942	2764	548	3312	3588	328	3917	2802	582	3384
Estimated Expected Response of Assigned Resources (MW)	2398	544	2942	2764	548	3312	2135	195	2330	1756	365	2121
Actual Response of Assigned Resources (MW)	1931	406	2337	2171	439	2610	2119	238	2357	1261	367	1628
Output Increase of Resources without Assignment (MW)	1961	0	1961	1575	0	1575	1371	0	1371	488	0	488
Percent Response To Assignment (%)	81%	75%	79%	79%	80%	79%	59%	72%	60%	45%	63%	48%
Percent Response To Estimated Expected Response (%)	81%	75%	79%	79%	80%	79%	99%	122%	101%	72%	101%	77%
Penalty (MW)	466	138	605	592	110	702	0	0	0	0	0	0

Event Counted Toward Qualifying Events	Qualifying Reason	Individual Percent Response To Assignment (%)	Average Percent Response To Assignment (%)
02/05/25 10:05:15	Duration ≥ 10 minutes	65.1%	74.4%
07/01/25 10:18:26	Duration ≥ 10 minutes	79.5%	
07/22/25 15:11:28	Duration ≥ 10 minutes	78.8%	

Load Forecast Report

Presenter/SME:

Marcus Smith,
Marcus.Smith@pjm.com

System Operations Report

Presenter:

David Kimmel,
David.Kimmel@pjm.com

SME:

Ross Kelly,
Ross.Kelly@pjm.com

A green speech bubble containing a white question mark, positioned above a blue speech bubble with three horizontal lines, which is in turn positioned above a yellow circle containing contact information.

?

Member Hotline

(610) 666 – 8980

(866) 400 – 8980



custsvc@pjm.com

Appendix

Goal Measurement: Balancing Authority ACE Limit (BAAL)


- The purpose of the new BAAL standard is to maintain interconnection frequency within a predefined frequency profile under all conditions (normal and abnormal), to prevent frequency-related instability, unplanned tripping of load or generation, or uncontrolled separation or cascading outages that adversely impact the reliability of the interconnection. NERC requires each balancing authority demonstrate real-time monitoring of ACE and interconnection frequency against associated limits and shall balance its resources and demands in real time so that its Reporting ACE does not exceed the BAAL ($BAAL_{LOW}$ or $BAAL_{HIGH}$) for a continuous time period greater than 30 minutes for each event.
- PJM directly measures the total number of BAAL excursions in minutes compared to the total number of minutes within a month. PJM has set a target value for this performance goal at 99% on a daily and monthly basis. In addition, current NERC rules limit the recovery period to no more than 30 minutes for a single event.

RTO Generation Outage Rate - Daily



The 13-month average forced outage rate is 5.09% or 10,097 MW.
The 13-month average total outage rate is 15.39% or 30,491 MW.

PCLLRW Count Vs. Peak Load – Daily Values For 13 Months



**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



Be alert to
malicious
phishing emails.

Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com

