


Regulation Performance Update


Ilyana Dropkin, Sr. Engineer
Performance Compliance
Operating Committee
September 11, 2025

Average Regulation Market Clearing Prices Per Month



*Data through 8/27/2025


Average Mileage Ratio Per Month



*Data through 8/27/2025

Average Marginal Benefits Factor Per Month

Monthly Average Marginal Benefits Factor



*Data through 8/27/2025

Season	Dates	Off-Ramp	On-Ramp	Effective MW Requirement
Winter	Dec 1 – Feb 29	HE1 – HE4, HE10 – HE16	HE5 – HE9, HE17 – HE24	Non-Ramp = 525MW Ramp = 800MW
Spring	Mar 1 – May 31	HE1 – HE5 HE9 – HE17	HE6 – HE8 HE18- HE24	Non-Ramp = 525MW Ramp = 800MW
Summer	Jun 1 - Aug 31	HE1 – HE5 HE15 – HE18	HE6 – HE14 HE19- HE24	Non-Ramp = 525MW Ramp = 800MW
Fall	Sep 1– Nov 30	HE1 – HE5 HE9 – HE17	HE6 – HE8 HE18- HE24	Non-Ramp = 525MW Ramp = 800MW

MW	Hydro	CT	DSR	Steam
Regulation A				
Avg. Performance Score (8/2024)	91%	89%	85%	80%
Avg. Performance Score (11/2024)	91%	88%	88%	81%
Avg. Performance Score (2/2025)	91%	88%	88%	82%
Avg. Performance Score (5/2025)	92%	88%	88%	82%
Avg. Performance Score (8/2025)	92%	88%	86%	83%
Regulation A Qualified MW (8/2025)	895	2034.4	19.0	5183.5

*Data through 8/28/2025

MW	Hydro	CT	Energy Storage	DSR
Regulation D				
Avg. Performance Score (8/2024)	78%	81%	90%	88%
Avg. Performance Score (11/2024)	78%	81%	90%	89%
Avg. Performance Score (2/2025)	78%	81%	90%	90%
Avg. Performance Score (5/2025)	78%	81%	90%	89%
Avg. Performance Score (8/2025)	78%	80%	91%	89%
Regulation D Qualified MW (8/2025)	334.0	132.4	310.8	55.5

*Data through 8/28/2025

How long the signal is automatically pegged

- RegD

	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug
20-30 min. duration	3	0	0	2	0	1	1	2	3	3	2	4	4	4	1	3
>30 min. duration	0	0	0	1	0	0	1	0	2	0	0	0	1	0	0	0

- RegA

	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug
20-30 min. duration	76	84	72	54	74	62	61	64	88	75	92	124	99	87	112	82
>30 min. duration	30	34	28	28	21	33	29	30	46	44	50	75	55	47	39	61

*Data through 8/28/2025

Regulation OC Update

SME/Presenter:

*Ilyana Dropkin,
Ilyana.Dropkin@pjm.com*

*Performance Compliance Department,
PerfCompDept@pjm.com*



Member Hotline

(610) 666 – 8980


(866) 400 – 8980

custsvc@pjm.com

**PROTECT THE
POWER GRID**
**THINK BEFORE
YOU CLICK!**



**BE ALERT TO
MALICIOUS PHISHING
EMAILS**



Report suspicious email activity to PJM.
Call (610) 666-2244 or email it_ops_ctr_shift@pjm.com