

Reporting status of the Eddystone Units:

Constellation will maintain active cost offers in Markets Gateway that reflects the prevailing costs based on Manual 15 to operate on gas or oil for both Eddystone 3 and 4, unless either fuel is unavailable or if the units are on a Planned, Maintenance or Forced outage. All outages will be reported via eDART and in alignment with Manuals 10 and 14D.

The units will be shown as 'unavailable' until PJM operators direct the units as outlined below.

PJM dispatch actions:

PJM may schedule and dispatch either or both of the units for reliability purposes to address:

- An identified reliability need in support of the requirement to operate such facilities within established thermal, voltage and stability limits under Sections 2 and 3 of [PJM Manual 3](#) and when such reliability needs cannot otherwise be met with available economically dispatched generating resources,
- A PJM reliability need caused by a system restoration need as described in [PJM Manual 36](#),
- A Capacity Emergency, as described in [PJM Manual 13](#), during which PJM determines that the resources scheduled for an operating day are not sufficient to maintain the appropriate reserve levels for PJM.

Constellation may also schedule the unit(s) for any needed testing, regulatory requirements, etc. provided advanced notification is provided to PJM of at least 20-minutes prior to starting the unit.