

Installed Reserve Margin (IRM), Forecast Pool Requirement (FPR), and Effective Load Carrying Capability (ELCC) for 2025/2026 3IA

Josh Bruno
Resource Adequacy Planning
Planning Committee
January 7, 2025

| ELCC Class | Effective Nameplate (MW) | Installed Capacity (MW) |
|--|--------------------------|-------------------------|
| Onshore Wind | 11,486 | 2,293 |
| Offshore Wind | Small Sample Size | Small Sample Size |
| Solar Fixed Panel | 1,844 | 832 |
| Solar Tracking Panel | 11,566 | 7,152 |
| Landfill Gas Intermittent | 167 | 118 |
| Hydro Intermittent | 736 | 519 |
| 4-hr Storage, 6-hr Storage, 8-hr Storage, 10-hr Storage | 5,609 | 5,609 |
| Solar-Storage Hybrid | Small Sample Size | Small Sample Size |
| DR | Not Applicable | 7,934 |
| Nuclear | Not Applicable | 32,147 |
| Coal | Not Applicable | 36,044 |
| Gas CC (Single and Dual Fuel) | Not Applicable | 56,719 |
| Gas CT | Not Applicable | 11,122 |
| Gas CT Dual Fuel | Not Applicable | 13,117 |
| Diesel | Not Applicable | 333 |
| Steam | Not Applicable | 9,851 |
| Hydro with Non-Pumped Storage | 2,034 | 1,969 |
| Other Thermal | Not Applicable | 3,151 |

| ELCC Class | Final Rating |
|---------------------------|--------------|
| Onshore Wind | 42% |
| Offshore Wind | 71% |
| Solar Fixed Panel | 8% |
| Solar Tracking Panel | 11% |
| Landfill Gas Intermittent | 51% |
| Hydro Intermittent | 37% |
| 4-hr Storage | 44% |
| 6-hr Storage | 53% |
| 8-hr Storage | 58% |
| 10-hr Storage | 67% |
| DR | 68% |
| Nuclear | 95% |
| Coal | 83% |
| Gas CC | 77% |
| Gas CT | 59% |
| Gas CT Dual Fuel | 78% |
| Diesel | 92% |
| Steam | 73% |



2025/26 3IA Final ELCC Class Ratings vs 2025/26 BRA Ratings

| ELCC Class | 2025/26 3IA Rating | 2025/26 BRA Rating | Change (%) |
|---------------------------|--------------------|--------------------|------------|
| Onshore Wind | 42% | 35% | +7 |
| Offshore Wind | 71% | 60% | +11 |
| Solar Fixed Panel | 8% | 9% | -1 |
| Solar Tracking Panel | 11% | 14% | -3 |
| Landfill Gas Intermittent | 51% | 54% | -3 |
| Hydro Intermittent | 37% | 37% | 0 |
| 4-hr Storage | 44% | 59% | -15 |
| 6-hr Storage | 53% | 67% | -14 |
| 8-hr Storage | 58% | 68% | -10 |
| 10-hr Storage | 67% | 78% | -11 |
| DR | 68% | 76% | -8 |
| Nuclear | 95% | 95% | 0 |
| Coal | 83% | 84% | -1 |
| Gas CC | 77% | 79% | -2 |
| Gas CT | 59% | 62% | -3 |
| Gas CT Dual Fuel | 78% | 79% | -1 |
| Diesel | 92% | 92% | 0 |
| Steam | 73% | 75% | -2 |


- The majority of ratings for Unlimited Resource ELCC Classes saw no or small changes
- The majority of the rest of the ELCC Classes saw changes that are consistent with a greater share of winter risk (i.e. increases for the wind classes and decreases for all the other classes)

Seasonal Changes in 25/26 3IA LOLE vs 25/26 BRA

25/26 3IA Results

Seasonal Share of LOLE = 0.1 days/year


■ Summer
■ Winter



25/26 BRA Results

Seasonal Share of LOLE = 0.1 days/year

■ Summer
■ Winter




Seasonal Changes in 25/26 3IA LOLH vs 25/26 BRA

25/26 3IA Results

Seasonal Share of LOLH = 0.41 hours/year


■ Summer
■ Winter



25/26 BRA Results

Seasonal Share of LOLH = 0.323 hours/year


■ Summer
■ Winter



Seasonal Changes in 25/26 3IA EUE vs 25/26 BRA


25/26 3IA Results

Seasonal Share of EUE = 2280.0 MWh/year



25/26 BRA Results

Seasonal Share of EUE = 1452.6 MWh/year



- The total amount of **ICAP** in the model is **188,920 MW**
- The **peak load** (“solved load”) that the above amount of ICAP can serve while meeting the LOLE criteria of 1 day in 10 years is **157,382 MW**
- The **Capacity Benefit of Ties** (CBOT) is assumed to be **1.5%**, the same value used in previous calculations
- Therefore, the **2025/26 3IA IRM** equals **18.5%**:
 - $\text{IRM} = [(188,920 / 157,382) - 1] - 1.5\%$
 - $\text{IRM} = [1.200 - 1] - 0.015 = 18.5\%$
- The total amount of **Accredited UCAP** in the model is **147,680 MW**
- The **Pool-Wide Average AUCAP Factor** is $147,680 / 188,920 = 0.7817$
- Therefore, the **2025/26 3IA FPR** equals **0.9263**
 - $\text{FPR} = (1 + 0.185) \times 0.7817 = 0.9263$

2025/26 3IA IRM and FPR vs 2025/26 BRA

| Parameter | 2025/26 3IA Value | 2025/26 BRA Value | Change |
|-------------------------------------|-------------------|-------------------|-----------|
| ICAP | 188,920 MW | 191,693 MW | -2,773 MW |
| “Solved Load” | 157,382 MW | 160,624 MW | -3,242 MW |
| CBOT | 1.5% | 1.5% | 0 |
| IRM | 18.5% | 17.8% | +0.7% |
| Accredited UCAP | 147,680 MW | 152,765 MW | -5,085 MW |
| Pool-Wide Average UCAP Factor | 0.7817 | 0.7969 | -0.0152 |
| FPR | 0.9263 | 0.9387 | -0.0124 |

- Endorsement of the following values for 2025/26 3IA
 - **IRM = 18.5%**
 - **FPR = 0.9263**

SME/Presenter:

Josh Bruno

Josh.Bruno@pjm.com

Chair:

Megan Heater

Megan.Heater@pjm.com

Secretary:

Ashwini Bhat

Ashwini.Bhat@pjm.com

FPR, IRM, & ELCC for 25/26 3IA



Member Hotline

(610) 666 – 8980

(866) 400 – 8980

custsvc@pjm.com

**PROTECT THE
POWER GRID
THINK BEFORE
YOU CLICK!**



Be alert to
malicious
phishing emails.

Report suspicious email activity to PJM.
(610) 666-2244 / it_ops_ctr_shift@pjm.com

