

# 2026/27 BRA IRM, FPR, and ELCC Class Ratings

## *Shift Towards More Winter Risk*

Josh Bruno, Molly Mooney, Patricio Rocha Garrido

Resource Adequacy Planning  
Special Planning Committee  
March 13, 2025

- Summary of 2026/27 BRA Results
  - Installed Reserve Margin
  - Forecast Pool Requirement
  - ELCC Class Ratings
- Drivers of winter risk shift
  - Demand and Supply side analysis

# *2026/27 BRA Results*

## 1. Resource Mix

### a. Notice of Intent to Offer (NOI):

Planned resources that submitted a Notice of Intent for the 2026/2027 BRA were included in the Assumed Resource Mix

### b. Installed Capacity Ratings (ICAP Ratings):

Resources ICAP Ratings were updated to reflect any 2026/2027 transitional system capability awarded

### c. Announced Deactivations:

All resources with announced deactivations scheduled to occur before June 1<sup>st</sup>, 2027 were removed from the assumed resource mix

## 2. Load Scenarios:

Hourly load profiles were derived using the 2025 PJM load forecast

## 3. Performance Data:

Based on data from June 1<sup>st</sup>, 2012 through May 31<sup>st</sup>, 2024

| ELCC Class  | Effective Nameplate (MW) | Installed Capacity (MW) |
|---|--------------------------|-------------------------|
| Onshore Wind  | 11,650                   | 3,549                   |
| Offshore Wind   | Small Sample Size        | Small Sample Size       |
| Fixed-Tilt Solar                                      | 2,367                    | 1,189                   |
| Tracking Solar  | 13,321                   | 8,713                   |
| Intermittent Landfill Gas                             | 167                      | 118                     |
| Intermittent Hydropower                               | 736                      | 519                     |
| Capacity Storage Resource (4, 6, 8, 10 Hour Duration) | 5,834                    | 5,834                   |
| Solar-Storage Hybrid                                  | Small Sample Size        | Small Sample Size       |
| Demand Resource                                       | n/a                      | 8,184                   |
| Nuclear   | n/a                      | 32,144                  |
| Coal  | n/a                      | 35,779                  |
| Gas Combined Cycle + Gas Combined Cycle Dual Fuel     | n/a                      | 57,664                  |
| Gas Combustion Turbine                                | n/a                      | 11,030                  |
| Gas Combustion Turbine Dual Fuel                      | n/a                      | 13,158                  |
| Diesel Utility  | n/a                      | 329                     |
| Steam   | n/a                      | 10,004                  |
| Hydropower with Non-Pumped Storage                    | 2,034                    | 1,969                   |
| Other Unlimited Resource                              | n/a                      | 3,041                   |

| ELCC Class                                   | Class Rating |
|--|--------------|
| Onshore Wind                                 | 41%          |
| Offshore Wind                                | 69%          |
| Fixed-Tilt Solar                             | 8%           |
| Tracking Solar                               | 11%          |
| Intermittent Landfill Gas                    | 50%          |
| Intermittent Hydropower                      | 38%          |
| Capacity Storage Resource (4-Hour Duration)  | 50%          |
| Capacity Storage Resource (6-Hour Duration)  | 58%          |
| Capacity Storage Resource (8-Hour Duration)  | 62%          |
| Capacity Storage Resource (10-Hour Duration) | 72%          |
| Demand Resource                              | 69%          |
| Nuclear                                      | 95%          |
| Coal   | 83%          |
| Gas Combined Cycle                           | 74%          |
| Gas Combustion Turbine                       | 60%          |
| Gas Combustion Turbine Dual Fuel             | 78%          |
| Diesel Utility                               | 91%          |
| Steam  | 73%          |





# 2025/26 3IA Final ELCC Class Ratings vs 2026/27 BRA Ratings

| ELCC Class                                   | 2025/26<br>3IA Rating | 2026/27<br>BRA Rating | Change<br>(%) |
|--|-----------------------|-----------------------|---------------|
| Onshore Wind                                 | 38%                   | 41%                   | +3            |
| Offshore Wind                                | 62%                   | 69%                   | +7            |
| Fixed-Tilt Solar                             | 10%                   | 8%                    | -2            |
| Tracking Solar                               | 14%                   | 11%                   | -3            |
| Intermittent Landfill Gas                    | 51%                   | 50%                   | -1            |
| Intermittent Hydropower                      | 37%                   | 38%                   | +1            |
| Capacity Storage Resource (4-Hour Duration)  | 55%                   | 50%                   | -5            |
| Capacity Storage Resource (6-Hour Duration)  | 65%                   | 58%                   | -7            |
| Capacity Storage Resource (8-Hour Duration)  | 68%                   | 62%                   | -6            |
| Capacity Storage Resource (10-Hour Duration) | 77%                   | 72%                   | -5            |
| Demand Resource                              | 77%                   | 69%                   | -8            |
| Nuclear                                      | 95%                   | 95%                   | -             |
| Coal   | 83%                   | 83%                   | -             |
| Gas Combined Cycle                           | 78%                   | 74%                   | -4            |
| Gas Combustion Turbine                       | 63%                   | 60%                   | -3            |
| Gas Combustion Turbine Dual Fuel             | 79%                   | 78%                   | -1            |
| Diesel Utility                               | 92%                   | 91%                   | -1            |
| Steam  | 74%                   | 73%                   | -1            |

- Changes in Class Ratings are consistent with a greater share of winter risk
- In addition to the winter risk, Gas Combined Cycle Class Rating is also being driven by changes in class membership
  - About 3,800 MW shifted from the Gas Combined Cycle Class to the Gas Combined Cycle Dual Fuel Class which contributed ~1-2% in the decrease of the Gas Combined Cycle Class Rating

# Seasonal Changes in 25/26 3IA vs 26/27 BRA





- The total amount of **ICAP** in the model is **193,738 MW**
- The **peak load** (“solved load”) that the above amount of ICAP can serve while meeting the LOLE criteria of 1 day in 10 years is **160,682 MW**
- The **Capacity Benefit of Ties** (CBOT) is assumed to be **1.5%**, the same value used in previous calculations
- Therefore, the **2026/27 BRA IRM** equals **19.1%**:
  - $\text{IRM} = [(193,738 / 160,682) - 1] - 1.5\%$
  - $\text{IRM} = [1.206 - 1] - 0.015 = 19.1\%$
- The total amount of **Accredited UCAP** in the model is **149,149 MW**
- The **Pool-Wide Average AUCAP Factor** is  $149,149 / 193,738 = \mathbf{0.7699}$
- Therefore, the **2026/27 BRA FPR** equals **0.9170**
  - $\text{FPR} = (1 + 0.191) \times 0.7699 = 0.9170$

| Parameter                       | 3 <sup>rd</sup> IA Value | BRA Value | Change  | Driving Factor                                       |
|---------------------------------|--------------------------|-----------|---------|--|
| ICAP (MW)                       | 188,920                  | 193,738   | 4,818   | Resource Mix Changes (primarily NOIs)                |
| “Solved Load” (MW)              | 158,357                  | 160,682   | 2,325   | Higher ICAP offset by Higher Extreme Winter Loads    |
| CBOT (%)                        | 1.5%                     | 1.5%      | 0%      | n/a  |
| Installed Reserve Margin (IRM)  | 17.8%                    | 19.1%     | 1.3%    | Resource Mix Changes and Higher Extreme Winter Loads |
| Accredited UCAP (MW)            | 150,438                  | 149,149   | -1,289  | Higher Extreme Winter Loads                          |
| Pool-Wide Average UCAP Factor   | 0.7963                   | 0.7699    | -0.0264 | Higher Extreme Winter Loads                          |
| Forecast Pool Requirement (FPR) | 0.9380                   | 0.9170    | -0.021  | Lower UCAP Factor                                    |


# *Drivers Towards Winter Risk*

- The PJM ELCC Model has the following objective
  - Accredit resources based on the expected performance during expected hours and days of risk during a future Delivery Year
- To accomplish that, it is necessary to:
  1. Identify the **expected hours and days** of risk given expected hourly patterns of supply and demand for a delivery year
  2. Identify the **expected marginal performance of resources** during the hours and days identified in #1


- **Narrowing Gap:** For the RTO, the gap between winter and summer peaks is narrowing.
- **Primary Reasons:**
  - Delivery Year: Runs from June to May.
  - Data Centers: Rapid growth is causing more load in January than the preceding summer. (approximately 60%)
  - Rooftop Solar: Growth in rooftop solar reduces summer peaks, but has minimal impact on winter peaks. (approximately 20%)
  - Forecasted trends: Effects of electrification of heating on the system (heat pumps). (approximately 20%)



# Load Adjustment Impact on Load Shape – 2025LF vs 2024LF




# Distributed Solar – Impact at Summer Peak





Winter impact from distributed solar is essentially zero due to time of peak.

# Monthly Demand Shape- 2025LF vs 2024LF









# Understanding the 26/27 BRA Class Ratings relative to 25/26 3IA Class Ratings - Supply

| ELCC Class  | Installed Capacity (MW) 26/27 BRA | Installed Capacity (MW) 25/26 3IA | Difference (MW) |
|---|-----------------------------------|-----------------------------------|-----------------|
| Onshore Wind  | 3,549                             | 2,293                             | +1,256          |
| Offshore Wind   | Small Sample Size                 | Small Sample Size                 |                 |
| Fixed-Tilt Solar                                      | 1,189                             | 832                               | +357            |
| Tracking Solar  | 8,713                             | 7,152                             | +1,561          |
| Intermittent Landfill Gas                             | 118                               | 118                               | 0               |
| Intermittent Hydropower                               | 519                               | 519                               | 0               |
| Capacity Storage Resource (4, 6, 8, 10 Hour Duration) | 5,834                             | 5,609                             | +225            |
| Solar-Storage Hybrid                                  | Small Sample Size                 | Small Sample Size                 |                 |
| Demand Resource                                       | 8,184                             | 7,934                             | +250            |
| Nuclear   | 32,144                            | 32,147                            | -3              |
| Coal  | 35,779                            | 36,044                            | -265            |
| Gas Combined Cycle + Gas Combined Cycle Dual Fuel     | 57,664                            | 56,719                            | +945            |
| Gas Combustion Turbine                                | 11,030                            | 11,122                            | -92             |
| Gas Combustion Turbine Dual Fuel                      | 13,158                            | 13,117                            | +41             |
| Diesel Utility  | 329                               | 333                               | -4              |
| Steam   | 10,004                            | 9,851                             | +153            |
| Hydropower with Non-Pumped Storage                    | 1,969                             | 1,969                             | 0               |
| Other Unlimited Resource                              | 3,041                             | 3,151                             | -110            |

Relative to the size of the system the ICAP differences are not that significant.

In addition, some of the additions are likely to drive a reduction in winter risk (e.g. wind) while other additions are likely to drive an increase in winter risk (e.g. solar)

# Sensitivity Analysis – Using 25/26 3IA Load Scenarios in 26/27 BRA Case

| ELCC Class                                      | 2025/26<br>3IA<br>Rating | 2026/27<br>BRA<br>Rating | Change<br>(%) | 2026/27<br>BRA Sensit.<br>Rating | Change 26/27<br>Sensit. vs. 25/26<br>3IA (%) |
|---|--------------------------|--------------------------|---------------|----------------------------------|--|
| Onshore Wind                                    | 38%                      | 41%                      | +3            | 38%                              | 0  |
| Offshore Wind                                   | 62%                      | 69%                      | +7            | 64%                              | +2   |
| Fixed-Tilt Solar                                | 10%                      | 8%                       | -2            | 10%                              | 0  |
| Tracking Solar                                  | 14%                      | 11%                      | -3            | 14%                              | 0  |
| Intermittent Landfill Gas                       | 51%                      | 50%                      | -1            | 52%                              | +1   |
| Intermittent Hydropower                         | 37%                      | 38%                      | +1            | 37%                              | 0  |
| Capacity Storage Resource<br>(4-Hour Duration)  | 55%                      | 50%                      | -5            | 57%                              | +2   |
| Capacity Storage Resource<br>(6-Hour Duration)  | 65%                      | 58%                      | -7            | 65%                              | 0  |
| Capacity Storage Resource<br>(8-Hour Duration)  | 68%                      | 62%                      | -6            | 68%                              | 0  |
| Capacity Storage Resource<br>(10-Hour Duration) | 77%                      | 72%                      | -5            | 77%                              | 0  |
| Demand Resource                                 | 77%                      | 69%                      | -8            | 76%                              | -1   |
| Nuclear   | 95%                      | 95%                      | 0             | 95%                              | 0  |
| Coal  | 83%                      | 83%                      | 0             | 84%                              | +1   |
| Gas Combined Cycle                              | 78%                      | 74%                      | -4            | 77%                              | -1   |
| Gas Combustion Turbine                          | 63%                      | 60%                      | -3            | 64%                              | +1   |
| Gas Combustion Turbine<br>Dual Fuel             | 79%                      | 78%                      | -1            | 80%                              | +1   |
| Diesel Utility                                  | 92%                      | 91%                      | -1            | 92%                              | 0  |
| Steam   | 74%                      | 73%                      | -1            | 75%                              | +1   |

If the 25/26 3IA Load Scenarios would have been used in the 26/27 BRA Case, the ELCC Class Ratings would have been very similar to those in the 25 3IA. The changes are plus/minus 1 or 2 percentage points or no changes (see far-right column).

This also allows to conclude that the change to the 26/27 BRA resources portfolio is not a large driver of the change in the 26/27 ELCC Class Ratings

# Sensitivity Analysis – Using 25/26 3IA Portfolio in 26/27 BRA Case

| ELCC Class                                      | 2025/26<br>3IA<br>Rating | 2026/27<br>BRA<br>Rating | Change<br>(%) | 2026/27<br>BRA Sensit.<br>Rating | Change 26/27<br>Sensit. vs. 25/26<br>3IA (%) |
|---|--------------------------|--------------------------|---------------|----------------------------------|--|
| Onshore Wind                                    | 38%                      | 41%                      | +3            | 42%                              | +4   |
| Offshore Wind                                   | 62%                      | 69%                      | +7            | 69%                              | +7   |
| Fixed-Tilt Solar                                | 10%                      | 8%                       | -2            | 8%                               | -2   |
| Tracking Solar                                  | 14%                      | 11%                      | -3            | 12%                              | -2   |
| Intermittent Landfill Gas                       | 51%                      | 50%                      | -1            | 49%                              | -2   |
| Intermittent Hydropower                         | 37%                      | 38%                      | +1            | 39%                              | +2   |
| Capacity Storage Resource<br>(4-Hour Duration)  | 55%                      | 50%                      | -5            | 48%                              | -7   |
| Capacity Storage Resource<br>(6-Hour Duration)  | 65%                      | 58%                      | -7            | 58%                              | -7   |
| Capacity Storage Resource<br>(8-Hour Duration)  | 68%                      | 62%                      | -6            | 62%                              | -6   |
| Capacity Storage Resource<br>(10-Hour Duration) | 77%                      | 72%                      | -5            | 72%                              | -5   |
| Demand Resource                                 | 77%                      | 69%                      | -8            | 69%                              | -8   |
| Nuclear   | 95%                      | 95%                      | 0             | 95%                              | 0  |
| Coal  | 83%                      | 83%                      | 0             | 82%                              | -1   |
| Gas Combined Cycle                              | 78%                      | 74%                      | -4            | 75%                              | -3   |
| Gas Combustion Turbine                          | 63%                      | 60%                      | -3            | 60%                              | -3   |
| Gas Combustion Turbine<br>Dual Fuel             | 79%                      | 78%                      | -1            | 78%                              | -1   |
| Diesel Utility                                  | 92%                      | 91%                      | -1            | 91%                              | -1   |
| Steam   | 74%                      | 73%                      | -1            | 72%                              | -2   |

If the 25/26 3IA Resource Portfolio would have been used in the 26/27 BRA Case, the ELCC Class Ratings would have been very similar to those in the 26 BRA. The changes in the far-right column are very similar to the changes observed in the 26/27 ELCC Class Ratings.

This also allows to conclude that the 26/27 BRA load scenarios are the largest driver of the change in the 26/27 ELCC Class Ratings.

- From Slide #14, it can be seen that extreme winter loads in the 2025 LF have higher magnitude even after controlling for annual peak load increases
  - For example, the 90/10 winter peak in the 2025 LF for DY 26/27 (used in the 26/27 BRA ELCC run) is 0.98 of the annual peak while the 90/10 winter peak in the 2024 LF for DY 25/26 (used in the 25/26 3IA ELCC run) is 0.96 of the annual peak.
    - That corresponds to a 2 percentage point (0.02) difference
  - Assuming an annual peak load of about 159,000 MW the above means that the extreme winter loads in the 26/27 BRA ELCC run are about 3,180 MW ( $0.02 \times 159,000$ ) greater than in the 25/26 3IA case


# Why is the 2025 LF having this impact on the 26/27 analysis

- The 25 3IA case has 13,106 hours with loss of load across the 40,300 scenarios
  - 9,247 in Dec, Jan, Feb and 3,687 in Jun, Jul, Aug
- The 26 BRA case has 15,999 hours with loss of load across the 40,300 scenarios
  - 12,961 in Dec, Jan, Feb and 2,745 in Jun, Jul, Aug
- The increase in the number of Dec, Jan, Feb loss of load hours in the 26 BRA is
  - $12,961 - 9,247 = 3,714$
- The decrease in the number of Jun, Jul, Aug loss of load hours in the 26 BRA is
  - $2,745 - 3,687 = - 942$



# Why is the 2025 LF having this impact on the 26/27 analysis

Histogram of Hourly Shortfall in Dec, Jan, Feb in 2026 BRA case



Approximately 4,000 winter hours in the 26 BRA case have a shortfall that is less than 2,707 MW. These hours are likely to have become new loss of load hours (relative to the 25 3IA case) due to the increase in extreme winter loads of about 3,180 MW. Also, 4,000 roughly matches the increase in winter loss of load hours in the 26 BRA case discussed in the previous slide.



# Impact of Seasonal Risk Share on ELCC Class Rating volatility

## Estimated Seasonal 26/27 ELCC Class Ratings

| ELCC Class                                   | Summer | Winter |
|--|--------|--------|
| Onshore Wind                                 | 10%    | 46%    |
| Offshore Wind                                | 22%    | 77%    |
| Fixed-Tilt Solar                             | 22%    | 6%     |
| Tracking Solar                               | 32%    | 7%     |
| Intermittent Landfill Gas                    | 58%    | 49%    |
| Intermittent Hydropower                      | 37%    | 39%    |
| Capacity Storage Resource (4-Hour Duration)  | 94%    | 43%    |
| Capacity Storage Resource (6-Hour Duration)  | 98%    | 52%    |
| Capacity Storage Resource (8-Hour Duration)  | 93%    | 57%    |
| Capacity Storage Resource (10-Hour Duration) | 97%    | 68%    |
| Demand Resource                              | 108%   | 63%    |
| Nuclear                                      | 96%    | 95%    |
| Coal   | 86%    | 82%    |
| Gas Combined Cycle                           | 95%    | 71%    |
| Gas Combustion Turbine                       | 96%    | 54%    |
| Gas Combustion Turbine Dual Fuel             | 96%    | 75%    |
| Diesel Utility                               | 96%    | 90%    |
| Steam  | 88%    | 70%    |

Annual ELCC Class Rating can be **approximated** by using the weighted average of the Seasonal Ratings, where the weights correspond to the seasonal LOLH shares.

For example, using the Offshore Wind class and the 26/27 BRA LOLH shares (0.82 and 0.18)

Approx. Annual Rating:  $0.82 \times 77\% + 0.18 \times 22\% = 67\%$


If instead we use the 25/26 3IA LOLH shares (0.71 and 0.29):



Approx. Annual Rating:  $0.71 \times 77\% + 0.29 \times 22\% = 61\%$

While the two values above do not necessarily match the 26/27 BRA and 25/26 3IA ratings for Offshore Wind, the difference between the two values above (67% vs 61%) provides a sense of how Class Ratings can vary based on seasonal risk shares shifting from one run to another run.

# Appendix Slides

Summer Distribution - PerUnitized on Annual Peak





SME/Presenters:

Josh Bruno, [Joshua.Bruno@pjm.com](mailto:Joshua.Bruno@pjm.com)

Molly Mooney, [Molly.Mooney@pjm.com](mailto:Molly.Mooney@pjm.com)

Patricio Rocha Garrido,

[Patricio.Rocha-Garrido@pjm.com](mailto:Patricio.Rocha-Garrido@pjm.com)

**2026/27 BRA IRM, FPR, and ELCC  
Class Ratings**

*Shift Towards More Winter Risk*



**Member Hotline**

(610) 666 – 8980

(866) 400 – 8980

[custsvc@pjm.com](mailto:custsvc@pjm.com)

**PROTECT THE  
POWER GRID  
THINK BEFORE  
YOU CLICK!**



Be alert to  
malicious  
phishing emails.

**Report suspicious email activity to PJM.**  
(610) 666-2244 / [it\\_ops\\_ctr\\_shift@pjm.com](mailto:it_ops_ctr_shift@pjm.com)

