

## 4.10 Other Related Studies Performed

### 4.10.1 Interim Deliverability Studies

#### 4.10.1.1 Applicability

---

PJM performs interim deliverability studies for two reasons:

1. Projects that request to come into service prior to the base case study year in which they are studied and
2. Projects that request to come into service prior to the construction of a required system reinforcement (~~FC~~contingent ~~F~~facilities). Contingent ~~facilities~~ Facilities are identified in the latest System Impact Study or in either (i) Specifications, sSection 3.d or (ii) Schedule F of the GIA or ISA. Contingent Facilities may be Network Upgrades, baseline upgrades, or Supplemental Project upgrades.

These studies are performed in order to determine whether a project is deliverable for all or a portion of ~~their~~ its output.

#### 4.10.1.2 Schedule for Interim Deliverability Studies

---

Requests for interim deliverability studies for a particular Delivery Year shall be made a minimum of ~~ten~~ eleven months prior to the start of that Delivery Year. PJM will only consider projects for interim deliverability analysis if a Project Developer initiates a request to be studied for a particular Delivery Year. PJM intends to provide interim deliverability results eight months prior to the start of the Delivery Year.

#### 4.10.1.3 Analysis for Interim Deliverability Studies

---

The interim deliverability study evaluates the system availability differently depending on the reason for the interim study. Projects requesting to come into service prior to the base case study year in which they were originally studied are evaluated against all violations. Projects that request to come into service prior to the construction of a needed system reinforcement Contingent Facility are only evaluated against the violations in which system reinforcement mediates.

The interim deliverability study results are only valid for the RPM auction Delivery Year on-for which they were studied. The Delivery Year is defined as June 1<sup>st</sup> of the first year to May 31<sup>st</sup> of the following year (e.g., the Delivery Year for the 2024/25 3rd Incremental Auction is considered to be from June 1<sup>st</sup> 2024 to May 31<sup>st</sup> 2025). The base case used for the interim study will be based off of an RTEP case of the Delivery Year under study.

The flowgate loading for the interim deliverability study performed follows the Generator Deliverability Procedure detailed in C.3 of Manual 14B.

A project is considered fully deliverable if the project only contributes to flowgates with a post study loading less than 100% or has a MW contribution less than 1% of the line rating to an overloaded flowgate. A project is considered not deliverable if the MW contribution is 1% or greater of the line rating of a previously overloaded flowgate.

For flowgates that are not overloaded prior to the interim deliverability study but are overloaded at the end of the interim deliverability study, deliverable MW's will be determined via a cluster study methodology and will be allocated proportionally based on the project's MW impact to the flowgate and distribution factor (DFAX).

At PJM's discretion, PJM may allow Provisional Interconnection Service for projects with Ceontingent Ffacilities to operate as energy-only resources for a particular Ddelivery Tyear. During such periods, PJM reserves the right to deny Provisional Interconnection Service for projects or to limit total injections for projects consistent with the results of the interim deliverability study (which may be less than the Maximum Facility Output).

The interim deliverability study shall include any additional studies necessary to evaluate a New Services Requests eligibility for Provisional Interconnection Service.

**Note:**

Even if a project is found to be deliverable or granted Provisional Interconnection Service for a particular Ddelivery Yyear, interim deliverability must be requested for each additional Delivery yYear that the conditions apply. An energy-only resource is eligible for Provisional Interconnection Service but not awarded Capacity Interconnection Rights.

#### **4.10.1.4 Eligibility Requirements for Interim Deliverability Studies**

---

Requests for interim deliverability studies for a particular Ddelivery Yyear shall be made a minimum of ~~ten-eleven~~ months prior to the start of that Ddelivery Yyear. Only projects with an executed GIA or ISA or have confirmation from their PJM Project Manager that they ~~will be~~ expected to receive a GIA ~~by prior to~~ the 3rd Incremental Auction ~~date~~ may participate in the interim deliverability study for that Ddelivery Yyear. Requests received after the start of the interim deliverability study will not be considered. Refer to PJM Capacity Market Manual 18, Section 4.2.4, for eligibility requirements to participating in a PJM RPM auction.