

SRRTEP Committee: Mid-Atlantic PSE&G FERC Form 715 Criteria Update

October 16, 2025

PSE&G FERC Form 715

Part 4 Update

- Per the below update, PSE&G will allow legacy series reactors to be replaced where deemed necessary.

VIII. Additional Considerations

C. SERIES REACTORS

Series reactors shall not be installed on circuits to control flow. Legacy reactors shall be retired if no longer required. If legacy reactors fail or are retired due to age and/or condition, **PSE&G will exercise its judgment based on good utility practice whether the legacy reactors shall be replaced or retired.** ~~they shall not be replaced,~~

Language
removed

Language
added