



Mid-Atlantic Sub Regional RTEP Committee
ACE
Supplemental Projects

July 17, 2026

Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

Need Number: ACE-2026-003

Process Stage: Need Meeting 07/17/2026

Project Driver: Operational Flexibility and Efficiency.

Specific Assumption Reference:

- Enhancing system functionality, flexibility, visibility, or operability.

Problem Statement:

- The Court T1 69/12kV distribution transformer has no high-side interrupting device; in the event of an outage on the transformer, the Court 69kV bus will be interrupted, opening two 69kV transmission lines into the substation.

