

SRRTEP Committee: Mid-Atlantic PSE&G Supplemental Projects

July 17, 2026

Needs

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process



PSE&G Transmission Zone M-3 Process Cherry Hill Area

Need Number: PSEG-2026-0003

Process Stage: Needs Meeting 07/17/2026

Supplemental Project Driver:

- Equipment Material Condition, Performance and Risk

Specific Assumption Reference:

[PSE&G 2026 Annual Assumptions](#)

[August 2017 26kV to 69kV PSE&G Presentation](#)

- Equipment Reliability and Condition Assessment
- Asset Risk Model

Problem Statement:

- Cherry Hill Station has been in service since 1955 and needs to be addressed due to deteriorating equipment material condition.
 - Cherry Hill Station serves a combined residential and commercial load of 10.7MVA.

Model: 2025 Series 2030 Summer RTEP 50/50

