

Subregional RTEP Committee – Mid-Atlantic FirstEnergy Supplemental Projects Penelec Transmission Zone

Solutions

Stakeholders must submit any comments within 10 days of this meeting in order to provide time necessary to consider these comments prior to the next phase of the M-3 process

Need Number: PN-2024-004

Process Stage: Solution Meeting – SRRTEP-MA – 08/13/2026

Previously Presented: Need Meeting – SRRTEP-MA – 03/14/2024

Project Driver:

Equipment Condition/Performance/Risk

Operational Flexibility and Efficiency

Specific Assumption References:

System Performance Global Factors

- Past system reliability/performance
- Substation/Line equipment limits

Line Condition Rebuild/Replacement

- Age/condition of wood pole transmission line structures

Problem Statement:

The Eagle Valley – Philipsburg 115 kV Line was constructed 68 years ago. The line is approximately 11.9 miles long with 98 wooden H-frame structures.

Recent inspections have identified that the line is exhibiting deterioration to its poles, arms, braces and attachment hardware.


- 50 structures failed inspection due to deteriorated condition of wood poles and hardware.
- 80 structures are 45 years or older.

Since 2019, the Eagle Valley – Philipsburg 115 kV Line experienced one unscheduled outage due to a broken cross arm.

The line is limited by terminal equipment.

Existing Eagle Valley – Philipsburg 115 kV Line Ratings:

- 137 / 174 / 171 / 190 MVA (SN/SE/WN/WE)



Need Number: PN-2024-004

Process Stage: Solution Meeting – SRRTEP-MA – 08/13/2026

Proposed Solution:

Rebuild approximately 11.9 miles of the EVP (Eagle Valley-Philipsburg) 115 kV line with a new conductor and upgrade terminal equipment to meet or exceed the new line rating. Adjust remote-end relaying as necessary.

Ratings:

Eagle Valley – Philipsburg 115 kV Line

- Before Proposed Solution: 137 / 174 / 171 / 191 MVA (SN/SE/WN/WE)
- After Proposed Solution: 232 / 282 / 263 / 334 MVA (SN/SE/WN/WE)

Alternatives Considered:

Maintain existing conditions with risk of equipment failure due to equipment deterioration.

Estimated Project Cost: \$38.41 M

Projected In-Service: 12/29/2028

Project Status: Conceptual

Model: 2024 RTEP model for 2039 Summer (50/50)

Penelec Transmission Zone M-3 Process Eagle Valley – Philipsburg 115 kV Line, PA



Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	

Appendix

High level M-3 Meeting Schedule

Assumptions	Activity	Timing
	Posting of TO Assumptions Meeting information	20 days before Assumptions Meeting
	Stakeholder comments	10 days after Assumptions Meeting
Needs	Activity	Timing
	TOs and Stakeholders Post Needs Meeting slides	10 days before Needs Meeting
	Stakeholder comments	10 days after Needs Meeting
Solutions	Activity	Timing
	TOs and Stakeholders Post Solutions Meeting slides	10 days before Solutions Meeting
	Stakeholder comments	10 days after Solutions Meeting
Submission of Supplemental Projects & Local Plan	Activity	Timing
	Do No Harm (DNH) analysis for selected solution	Prior to posting selected solution
	Post selected solution(s)	Following completion of DNH analysis
	Stakeholder comments	10 days prior to Local Plan Submission for integration into RTEP
	Local Plan submitted to PJM for integration into RTEP	Following review and consideration of comments received after posting of selected solutions

Revision History

08/03/2026 – V1 – Original version posted to pjm.com