

FirstEnergy – MetEd – 2025  
Submission of Supplemental Projects for  
Inclusion in the Local Plan

# Met-Ed Transmission Zone M-3 Process Middletown Junction – Swatara Hill – Campbelltown 69 kV Line

**Need Number:** ME-2019-009  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan  
**Previously Presented:** Solution Meeting 03/13/2025  
 Need Meeting 02/22/2019

**Project Driver:**

Equipment Condition/Performance/Risk


**Specific Assumption References:**

Line Condition Rebuild/Replacement

- Age/condition of wood pole transmission line structures
- Age/condition of steel tower or steel pole transmission line structures
- Age/condition of transmission line conductors System Performance Projects
- Substation/line equipment limits

**Problem Statement:**

- Line sections are exhibiting deterioration, increasing maintenance needs. Transmission line is approaching end of life
- Transmission line ratings are limited by terminal equipment.



ME-2019-	Transmission Line / Substation Locations	Existing Circuit Rating (SN / SE)	Existing Conductor Rating (SN / SE)	Limiting Terminal Equipment	Length of Line (miles)	Identified Structures (end of life / total)	Failure reasons
009	Campbelltown – Swatara Hill 69 kV Line	71 / 90	74 / 90	Substation Conductor	10.5	57 / 288 (20% Failure Rate)	Age, top rot, voids, woodpecker holes
	Swatara Hill – Middletown Junction 69 kV Line	71 / 91	121 / 150	Substation Conductor, Disconnect Switches	2.5		

**Need number:** ME-2019-009  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Selected Solution:**

**Middletown Junction – Swatara Hill – Campbelltown 69 kV Line:**

- Rebuild approximately 9 miles of Campbelltown – Middletown Junction 69 kV Line.


**Middletown Junction 69 kV Substation:**

- At Middletown Junction Review and revise relaying.

**Campbelltown 69 kV Substation:**

- At Campbelltown Substation Review and revise relaying.

**Estimated Project Cost:** \$25.4 M  
**Projected In-Service:** 12/31/2026  
**Supplemental Project ID:** s3622.1



Legend	
500 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
New	

**Need Number:** ME-2019-053

**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Previously Presented:** Solution Meeting – 12/12/2024  
Need Meeting – 06/28/2019


**Project Driver:**  
*Customer Service*

**Specific Assumption Reference:**

Customer request will be evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

**Problem Statement:**

New Customer Connection – A customer requested 115 kV service; anticipated load is 28 MVA; location is near the Raintree Substation



**Need Number:** ME-2019-053  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Selected Solution:**

- Construct a four-breaker 115 kV ring bus at Raintree Substation
- Remove existing temporary configuration connection at Raintree
- Loop the Middletown Junction – Smith Street 115 kV 978 Line into Raintree Substation

**At Raintree Substation**

- Install one control house
- Install four 115 kV circuit breakers and associated disconnect switches
- Install two standard transmission line relay panels

**At Middletown Junction Substation**

- Replace existing line relay panels


**At Willis Road (Smith Street) Substation**

- Replace one 115 kV circuit breaker and associated disconnect switches
- Replace existing line relay panels

**Estimated Project Cost:** \$12.5M

**Projected In-Service:** 12/31/2026

**Supplemental Project ID:** s3623.1



Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	

**Need Number:** ME-2023-013  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan  
**Previously Presented:** Solution Meeting – 12/12/2024  
 Need Meeting – 11/16/2023

**Project Driver:**  
*Operational Flexibility and Efficiency*


**Specific Assumption Reference:**

System Performance Projects

- Add/Expand Bus Configuration
- Load at risk in planning and operational scenarios
- Reduce the amount of exposed potential local load loss during contingency conditions
- Eliminate simultaneous outages to multiple networked elements

**Problem Statement:**

A fault on the North Lebanon – West Lebanon 69 kV Line, a fault on the 69 kV bus at Cleona Substation, or a fault on the Cleona No. 1 transformer results in the loss of Cleona Substation. Cleona Substation serves approximately 2,080 customers and 11 MW.




**Need Number:** ME-2023-013  
**Process State:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Selected Solution:**

At Cleona Substation

- Construct a three breaker 69 kV ring bus by installing three 69 kV circuit breakers and associated disconnect switches
- Install three standard transmission line relay panels
- Re-terminate the North Lebanon – West Lebanon 69 kV 94 Line into Cleona

**Estimated Project Cost:** \$9.5M  
**Projected In-Service:** 6/8/2026  
**Supplemental Project ID:** s3625.1



Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	

**Need Number:** ME-2023-017

**Process Stage:** Submission of Supplemental Project for Inclusion in the Local Plan

**Previously Presented:** Solution Meeting – 08/15/2024  
Need Meeting – 11/16/2023

**Project Driver:**  
*Operational Flexibility and Efficiency*


**Specific Assumption Reference:**

System Performance Projects

- Add/Expand Bus Configuration
- Load at risk in planning and operational scenarios
- Reduce the amount of exposed potential local load loss during contingency conditions
- Eliminate simultaneous outages to multiple networked elements

**Problem Statement:**

Mountain Substation can be outaged from a fault on the 115 kV bus, a fault on the No. 1 or No. 2 115-13.2 kV transformers, a fault on the Mountain CT transformer, or a stuck breaker on the PPGI or Gardners 115 kV line exits. Mountain Substation serves 7,320 customers and approximately 31.8 MW.






**Need Number:** ME-2023-017  
**Process Stage:** Submission of Supplemental Project for Inclusion in the Local Plan

**Selected Solution:**

- Convert Mountain 115 kV into a six-breaker ring bus
- At PPGI, replace one 115 kV circuit breaker

**Estimated Project Cost:** \$11.4M  
**Projected In-Service:** 12/31/2026  
**Supplemental Project ID:** s3605.1, s3605.2



Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	

**Need Number:** ME-2023-022  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan  
**Previously Presented:** Solution Meeting 11/6/2024  
 Needs Meeting 12/05/2023

**Project Driver:**  
*Operational Flexibility and Efficiency*

**Specific Assumption Reference:**


System Performance Projects

- Add/Expand Bus Configuration
- Load at risk in planning and operational scenarios
- Reduce the amount of exposed potential local load loss during contingency conditions
- Eliminate simultaneous outages to multiple networked elements

**Problem Statement:**

Multiple stuck breaker contingencies at North Hershey Substation or a fault on the 69 kV bus at North Hershey Substation results in the loss of two 69 kV networked elements and one 230-69 kV transformer.

The N-1-1 loss of the 230-69 kV transformer at North Hershey Substation followed by a 69 kV outage causes low voltage at multiple 69 kV buses.



**Need Number:** ME-2023-022  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan


**Selected Solution:**

- Convert the 69 kV bus at North Hershey Substation into a four-breaker ring bus
- Install a 2<sup>nd</sup> 230-69 kV transformer at North Hershey Substation
- At North Hershey Substation:
  - Install one 230 kV, 3000 A circuit breaker and associated equipment
  - Install four 69 kV, 3000 A circuit breakers and associated equipment

**New Transformer Ratings:**

- 211 / 217 / 260 / 268 MVA (SN/SE/WN/WE)

**Estimated Project Cost:** \$16.31M  
**Projected In-Service:** 12/17/2027  
**Supplemental Project ID:** s3624.1



Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	

**Need Number:** ME-2024-014  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan  
**Previously Presented:** Solution Meeting 1/16/2025  
 Need Meeting 5/16/2024

**Project Driver:**  
*Operational Flexibility and Efficiency*


**Specific Assumption Reference:**

System Performance Projects

- Add/Expand Bus Configuration
- Load at risk in planning and operational scenarios
- Reduce the amount of exposed potential local load loss during contingency conditions
- Eliminate simultaneous outages to multiple networked elements

**Problem Statement:**

Belfast Substation serves approximately 78 MW of load and 12,100 customers. A transformer fault, bus fault, or stuck breaker would result in a complete outage of the substation.




**Need Number:** ME-2024-014  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Selected Solution:**

- Construct a four breaker 115 kV ring bus at Belfast Substation:
  - Install four 115 kV circuit breakers, disconnect switches, line traps, and relaying.
  - Update relaying at North Bangor and Glendon substations.
  - Re-terminate the North Bangor and Northwood 115 kV terminals at Belfast Substation.

**Estimated Project Cost:** \$14.3M  
**Projected In-Service:** 6/1/2028  
**Supplemental Project ID:** s3626.1




Legend	
500 kV	
345 kV	
230 kV	
138 kV	
115 kV	
69 kV	
46 kV	
34.5 kV	
23 kV	
New	

**Need Number:** ME-2024-018  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan  
**Previously Presented:** Solution Meeting – 08/15/2024  
 Need Meeting – 07/18/2024

**Project Driver(s):**  
*Customer Service*

**Specific Assumption Reference(s)**  
 New customer connection request will be evaluated per FirstEnergy’s “Requirements for Transmission Connected Facilities” document and “Transmission Planning Criteria” document.

**Problem Statement**  
 New Customer Connection – A customer requested a new 69 kV delivery point near the Alcoa – Broad Street 69 kV Line. The anticipated load of the new customer connection is 39 MVA. The requested delivery point location is near the North Cornwall Substation.



# Met-Ed Transmission Zone M-3 Process

## Alcoa – Broad Street 69 kV Line Customer Connection


**Need Number:** ME-2024-018  
**Process Stage:** Submission of Supplemental Projects for Inclusion in the Local Plan

**Selected Solution:**

**69 kV Transmission Line Tap**

- Install one SCADA controlled transmission line switch
- Relocate SW 9206 at/near STR. 92-81
- Construct approximately 1-2 spans of transmission line using from tap to customer
- Install one 69 kV revenue metering package at customer substation
- Modify relay settings at Alcoa and Broad St. substations

**Estimated Project Cost:** \$1.19 M  
**Projected In-Service:** 11/24/2025  
**Supplemental Project ID:** s3627.1



Legend	
500 kV	
345 kV	
115 kV	
69 kV	
34.5 kV	
23 kV	
New	

# Revision History

09/26/2025 – V1

s3605

s3622

s3623

s3624

s3625

s3626

s3627