

PSEG 2025  
Submission of Supplemental Projects for  
Inclusion in the Local Plan

**Need Number:** PSEG-2023-0005

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 01/06/2025

**Previously Presented:**

- Need Meeting 05/18/2023
- Solutions Meeting 07/20/2023

**Supplemental Project Driver:**

- Equipment Material Condition, Performance and Risk

**Specific Assumption Reference:**

[PSE&G 2023 Annual Assumptions](#)

- Equipment Criticality, Consequence of Failure

**Problem Statement:**

- The cable connecting Newark and Bayonne 69kV networks is a high pressure fluid-filled circuit and is an environmental risk. The high pressure fluid-filled line was constructed in 1963. The line length totals to 2.3 miles with approximately 4800 feet underwater in the Newark Bay.
- The circuit contains over 23,000 gallons of dielectric fluid. There is a potential risk of an un-controlled leak of up to 56% of that fluid into Newark Bay.

**Model:** 2022 Series 2027 Summer RTEP 50/50



**Need Number:** PSEG-2023-0005

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 01/06/2025

**Selected Solution:**


- Replace the High Pressure Fluid Filled (HPFF) cable with Extruded Pipe (EP) cable.
  - Replace 2.3 miles of HPFF cable with EP cable.
  - Re-use the existing pipe and route for the cable replacement.
  - Modify terminal equipment at PVSC and Bayonne stations to accommodate the EP cables
  - At Bayonne station, de-commission and remove the oil pumping equipment including pumping plant, tank, controls, and piping associated with the cable.

**Estimated Cost:** \$25.6M

**Projected In-Service:** 12/2025

**Supplemental Project ID:** s3007.1

**Project Status:** Engineering and Planning





**Need Number:** PSEG-2024-0005

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 04/08/2025

**Previously Presented:**

- Need Meeting 12/12/2024
- Solutions Meeting 01/16/2025

**Supplemental Project Driver:**

- Customer Service

**Specific Assumption Reference:**

[PSE&G 2024 Annual Assumptions](#)

- Customer Substations

**Problem Statement:**

- A data center developer has submitted a request for a new 69kV interconnection point to serve a large single customer load in Middlesex County with a total load of 35 MW. Requested in-service date is 06/2026.

Initial In-Service Load – 5MW
Projected 2030 Load – 35MW

**Model:** 2022 Series 2027 SUM



**Need Number:** PSEG-2024-0005

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 04/08/2025

**Selected Solution:**


- Cut and loop 69kV line from Ridge Road Station to West Windsor Station into customer's new station.

**Estimated Cost:** \$3.4M

**Projected In-Service:** 06/30/2026

**Supplemental Project ID:** s3570

**Project Status:** Engineering and Planning





**Need Number:** PSEG-2023-0011

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 04/17/2025

**Previously Presented:**

- Need Meeting 10/31/2023
- Solutions Meeting 12/03/2024

**Supplemental Project Driver:**

- Customer Service

**Specific Assumption Reference:**


[PSE&G 2023 Annual Assumptions](#)

- Localized Load Growth & Contingency Overloads

**Problem Statement:**

- Lumberton Substation is a station in the Lumberton area with no additional station capacity.
  - Lumberton serves over 17,000 customers with a peak load of over 73.2 MVA in 2022.
  - The actual station capacity is 59.41 MVA. Contingency overload is 115%.

**Model:** 2022 Series 2027 Summer RTEP 50/50



**Need Number:** PSEG-2023-0011

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 04/17/2025

**Selected Solution:**

**At Pemberton:**


- Construct a 230-13kV Substation at PSEG owned property in the Pemberton Area.
  - Construct a 230kV substation.
  - Cut and loop Lumberton-Cookstown 230kV circuit into new substation.
  - Install two (2) 230-13kV transformers.
  - Estimated Cost: \$62.7M
- First Energy (JCP&L) to install a Fiber Connection on JCP&L owned portion from Pemberton to Cookstown.
  - First Energy (JCP&L) Estimated Cost: \$1.8M

**Total Project Cost : \$64.5M**

**Projected In-Service:** 12/2029

**Supplemental Project ID:** s3569

**Project Status:** Engineering and Planning





## PSEG Transmission Zone M-3 Process East Rutherford Area

**Need Number:** PSEG-2024-0002

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 04/28/2025

**Previously Presented:**

- Need Meeting 5/16/2024
- Solutions Meeting 8/15/2024

**Supplemental Project Driver:**

- Equipment Material Condition, Performance and Risk

**Specific Assumption Reference:**


[PSEG 2024 Annual Assumptions](#)

- Equipment Criticality, Consequence of Failure

**Problem Statement:**

- The East Rutherford 138/26 kV transformers No. 132-1 and 132-2 are exhibiting oil and nitrogen leaks, allowing moisture intrusion to accelerate the deterioration of the dielectric insulation system. These transformers are 65 years old with an increased probability of failure.

**Model:** 2023 Series 2028 Summer RTEP 50/50







**Need Number:** PSEG-2024-0002

**Process Stage:** Submission of Supplemental Project for inclusion in the Local Plan 04/28/2025

**Selected Solution:**


- Replace existing transformers 132-1 and 132-2 with six (6) single-phase transformers (3 per bank)
- Install one (1) additional single-phase transformer to be used as a spare in the event of failure of one of the in-service transformers
- Add one (1) additional 138kV bus-tie circuit breaker to existing 138kV straight bus
- Add two (2) 138kV transformer head breakers
- **Estimated Cost: \$43.1M**

**Projected In-Service: 5/31/2028**

**Supplemental Project ID:** s3604

**Project Status:** Engineering and Planning

# EAST RUTHERFORD



Legend:

-  In Service 138kV
-  New Project

# Revision History

1/06/2025 – V1 – s3007.1

4/8/2025 – V2 – s3570

4/17/2025 –V3 – s3569

4/28/2025 –V4 – s3604